



Albert Munoz <dfengineering.pc5@gmail.com>

Sidewalk Shed Removal (Full) - Rejected

1 message

DOBNOW donotreply <dobnowdonotreply@buildings.nyc.gov>
To: ALBERT MUNOZ <DFENGINEERING.PC5@gmail.com>

Mon, Jul 31, 2023 at 12:13 PM

This email references Site Safety Release request SSR-102987323-01-01 at 115 CHRYSTIE STREET , MANHATTAN .

The Sidewalk Shed Removal (Full) has been rejected by the Construction Safety Compliance unit for the following reason(s):

This is not a major building. It's under 10 stories and less than 100,000 sf of footprint. Therefore, an inspection for removing the SWS is not required. Notify the department through the DOB NOW between 24-48 hrs. of removing SWS.

This is an automated message. Please do not reply. If you have any questions, submit an inquiry at www.nyc.gov/dobnowhelp.

DOB NOW Support

NYC Department of Buildings.

