



FDNY

www.nyc.gov/fdny

DEPT OF BLDGS 121189515 Job Number

ES167018338 Scan Code

42797936

157 REST LLC
157 W 18TH ST
NEW YORK, NY 10011-4163
KID PIZZA

FPIMS/DOB/SBS APPLICATION: ALL ELECTRIC
FD PLAN NUMBER: 2024-TMRGHD-006429-AMND
ACCOUNT NUMBER: 42797936
DATE OF APPROVAL: 11/08/2024
DATE OF INSPECTION: 11/06/2024
INSPECTOR NAME: Thomassina Brown
FLOOR(S) INSPECTED: 001

PREMISES

157 West 18 Street Manhattan NY 10011

BOROUGH

MANHATTAN

LETTER OF APPROVAL RANGEHOOD INSPECTION UNIT

THIS LETTER OF APPROVAL COVERS THE DEVICES, EQUIPMENT AND/OR SYSTEMS INDICATED BELOW. IT IS SUBJECTED TO ADMINISTRATIVE REVIEW AND AUDIT. APPROVAL OF THE DEVICE, EQUIPMENT AND/OR SYSTEM(S) IS GRANTED IN ACCORDANCE WITH THE FOLLOWING LAWFUL PROCEDURE.

- ☒ INSPECTION/TEST
- ☐ INSPECTION AND CERTIFICATION OF CORRECTION OF DEFECTS BY A LICENSED PROFESSIONAL (3 RCNY 104-04)
- ☐ PROFESSIONAL CERTIFICATION (3RCNY 104-02)
- ☐ OTHER PROFESSIONAL CERTIFICATION/PROCEDURE PURSUANT TO (SPECIFY AUTHORITY):

Description of Devices:

Wet Chemical FES
System 1: Pyrochem PCL-460

Coverage Item	Quantity	Details
ADDITIONAL INFORMATION:		

By the Authority of
Chief of Fire Prevention

Fire Department, City of New York
9 MetroTech Center, Brooklyn New York 11201-3857



FDNY



42797936

www.nyc.gov/fdny

Floor No	Hood	Appliance	Nozzles	Description
001	A	OVN-Oven	0	
001	B	IND-Induction Cooker	2	
001	B	IND-Induction Cooker	2	
001	B	SAL-Salamander	1	
001	B	FRI-Refrigerator	0	
001	B	FFR-Fat Fryer	1	