



10/4/2017

Vincent Sapienza, P.E.  
Acting Commissioner

Anastasios Georgelis, P.E.  
Acting Deputy Commissioner  
Bureau of Water &  
Sewer Operations

59-17 Junction Boulevard  
Flushing, NY 11373

Bicaluro Associates, P.C.  
207 Yellowknife Road  
Morganville, New Jersey 07751  
Attn: Lucian Nicolescu, P.E.

To Whom It May Concern:

The hydrant flow test you requested in the vicinity of **416 Lenox Avenue, Manhattan** was performed on **10/3/2017** at **12:03 PM** with the following results:

The static pressure taken on a 12 inch water main which is fed from two directions on the east side of Lenox Avenue 1st hydrant north of West 131st Street was **44** pounds per square inch. The residual pressure at this point was **43** pounds per square inch when 500 gallons of water per minute were flowing from the north side of West 131st Street 1st hydrant east of Lenox Avenue.

This Department cannot guarantee that this pressure will be maintained in the future because a change may be needed in conformity with good engineering practices.

If you have any questions regarding engineering, and application status, please call (718) 595-7135.

Very truly yours,

Urszula Krajewski, P.E.  
Water Distribution Engineer  
City Wide Hydraulic Testing Unit

File: FT2017-2327-105403

All hydrant flow test requests are to be addressed to: NYCDEP-BWSO; 59-17 Junction Blvd, 12<sup>th</sup> Fl., Flushing; NY 11373-5108, Attn: Citywide Hydraulic Flow Test Unit

**Enclose payment for \$500 payable to NYC Water Board for each test.** Indicate the test street, cross streets and borough for each test. All requests are to be made by US or overnight mail, no hand deliveries accepted.