



FIRE DEPARTMENT

9 METROTECH CENTER

BROOKLYN, N.Y. 11201-3857



Date: 1/7/14

NYC Department of Buildings
Plumbing Section

Borough of: ☐ Bronx ☐ Brooklyn ☐ Queens ☒ Manhattan ☐ Staten Island

Re: Rest. Name: Pippali
Premise Address: 129 E. 27 ST
Borough / Zip: N.Y. 10016
DOB / FP Appl. No.: UPGRADE
Fire Department Plan No.: 33268863
DOB Cooking Equipment Job #: _____

Dear Sir / Madam:

On 1/7/14 a Fire Department representative witnessed a performance test of the Pyrochem PL-600 system at the subject premise. The test was satisfactory.

NOTE: ** Gas shut-off valve subject to the approval by the Department of Buildings.

** Occupancy. ☒ Under 75 Persons ☐ Over 75 Persons

BY ORDER OF CHIEF OF FIRE PREVENTION

THOMAS JENSEN

Prepared by: F.P.I. GARY CARWELL
Name and Title

Copy to: OWNEN FD Tag No.: 0001

Copy to: FD-01 FILE FIRE COMMAND