



NYC DEPA

DEPT. BLDGS.

122024870

Job Number

59-17 J

SC131212021

Scan Code

ASBESTOS ASSESSMENT REPORT

RECEIVED

5/15/2014

DEP
ASBESTOS CONTROL
PROGRAM

FEE PAID

1. NYC DOB Job # (if applicable) _____

Control Number: 1126429

2. Premise No. 174 Street Name East 2nd Street Borough Manhattan Zip 100093. AKA _____ Type of Facility _____ BIN 1004983 Block 00398 Lot 00524. Building Owner Village KF2 Associates LLC Address c/o Patrick Crosetto, 504 East 12th Street5. City New York State NY Zip 10009 Contact Person Patrick Crosetto6. Tel. # 2125332224 Fax # _____ Email _____

7. Description of the Entire Scope of Work

Install 2 water heaters with storage tank and associated gas piping with new meter set. This is a re-issue due to a clerical error.

8. I, JOSEPH MAFFUCCI, have conducted an asbestos investigation on

Name of Certified Asbestos Investigator

05/09/2014 in accordance

Date(s)

with Sections 1-16 and 1-28 of the NYC DEP Asbestos Control Program Rules and declare that at said facility address, the

☒ a. portion(s) of the premises affected by the work is free of asbestos containing material (ACM).☐ b. premise (or portions thereof) affected by the work contains 10 square feet or less or 25 linear feet or less of ACM.

Specify locations in section 9: Note: This material must be abated as a minor project in accordance with relevant provisions of the DEP Asbestos Rules.

☒ c. asbestos is present and will not be disturbed during construction activity. Specify the quantity and area where asbestos is present. Specify amount: 190 sq. ft 250 linear ft.

Specify locations (attach additional documents as necessary):

Assumed boiler insulation under metal jacket & pipe covering outside scope of work area - not to be disturbed.

☐ d. entire building is free of asbestos containing material (ACM).

9. RESULTS OF ASBESTOS BUILDING SURVEY:

FLOOR	DESCRIBE SECTION OF FLOOR	ALL MATERIALS ASSUMED TO CONTAIN ACM AND/OR SAMPLED	NUMBER OF SAMPLES ANALYZED	ASBESTOS PRESENT	ASSUMED ACM
Cellar	Boiler Room	Existing boiler insulation under metal jacket is assumed and not to be disturbed.	0	Yes	Yes
Cellar	Boiler Room/Entire Cellar	Any and all pipe covering outside of work area in boiler room as well as entire cellar assumed, not to be disturbed.	0	Yes	Yes

I hereby declare the information provided herein is true and complete

JOSEPH MAFFUCCI5/15/20141172024/2/2016

DEP Certified Asbestos Investigator's Signature

Date

Certificate Number

Expiration Date

Tel. # (718) 331-4160 Fax # (718) 331-4204 Email onlymatch@aol.com

The investigator shall assume that some or all of the areas investigated contain ACM, and for each area that is not assumed to contain ACM, collect and submit for analysis bulk samples in accordance with §§ 1-36, 1-37, and 1-44 of the DEP Asbestos Rules and EPA publications 560/5-85-024 and 560/5-85-030a and 40 CFR 763.86.

SEAL
OF THE
NYC DEP
CERTIFIED
ASBESTOS
INVESTIGATOR

25133189