



DEPT OF BLDGS 122046017

Job Number




ES753862107

Scan Code

122046017



AI1: Additional Information *Must be typewritten.*

Page number 1 of 1BIS Document No. 1

1 Location and Job Information *Required for all applications.*

House No(s) 349Street Name WEST 141 STREETBorough ManhattanBlock 2051Lot 6BIN 1089288CB No. 109

2 Revisions to Plans/Drawings *Required whenever updating plans. All revisions for each page must be clearly described in section 3.*

Submission is part of a Post Approval Amendment (PAA)? ☐ Yes *PW1 required* ☐ No *Indicate all actions for this submission:*

Action	Original/New/ Omit Page ID	Superseding Page ID	Action	Original/New/ Omit Page ID	Superseding Page ID	Action	Original/New/ Omit Page ID	Superseding Page ID	Action	Original/New/ Omit Page ID	Superseding Page ID

For "Action" use "N" for new page, "S" for superseding page, "O" for omitting page.

Is this section continued on additional AI1 forms? ☐ Yes ☐ No

3 Additional Information *Required for all applications.*

OBJ#1: Pedestrian ramps shall comply with DOT standard H-1011 – Show compliance on the plan.
 ANS: NO PEDIESTRIAN RAMPS REQUIRED FOR THIS PROJECT.

OBJ#2: On Drawing BPP-001.00, please clarify if grating shown is a Con Edison Vault or other agency.
 ANS: NO VAULTS ARE ASSOCIATED WITH THIS PROJECT.

OBJ#3: Provide DOB Curb Cut application number. (file separate application)
 ANS: THERE ARE NO CURB CUTS ASSOCIATED WITH THIS PROJECT AS WELL AS, THERE ARE NO EXISTING CURB CUTS ON FILE.

OBJ#5: Show on plan (and provide note) non-distinctive sidewalk: concrete slab pattern shall be 5' by 5' and concrete color shall be original. Provide NYC Art Commission approval for distinctive sidewalk - if different material, size, or color.
 ANS: NOTE PROVIDED INDICATING THE SIDEWALK IS NON-DISTINCTIVE PATTERN AND THEREFORE NEED NOT ATTAIN NYC ART COMMISSION APPROVAL.

OBJ#8: Provide Grade study on plan – indicate proposed Transverse slopes and Longitudinal slopes: Recommended Transverse slopes: 1.67% minimum and 5% maximum. Recommended Longitudinal slopes: 0.5% minimum and 5% maximum.
 ANS: NOTED ON BPP-002.00

OBJ#9: Provide TR2 and TR3 for concrete cast in place.
 ANS: Not required as concrete is less than 50 cubic yards.

OBJ#10: File fence work type with DOB NOW.
 ANS: Fence filed. #M00435694.

OBJ#11: Clarify how the egress will be maintained during work from the building
 ANS: ALL WORK IS TO BE CONDUCTED AS IT PERTAINS TO THE SIDEWALK PRIOR TO THE OCCUPANCY OF THE NEW BUILDING. SEE SITE SAFETY PLAN ASSOCIATED WITH JOB # 121205800.

OBJ#12: State on each plan: "Replacement of the existing curb cut, sidewalk slab and curb is not part of this application and shall be filed with NYC DOT".
 ANS: NOTE PLACED ON DRAWINGS

Falsification of any statement is a misdemeanor and is punishable by a fine or imprisonment, or both. It is unlawful to give to a city employee, or for a city employee to accept, any benefit, monetary or otherwise, either as a gratuity for properly performing the job or in exchange for special consideration. Violation is punishable by imprisonment or fine or both. I understand that if I am found after hearing to have knowingly or negligently made a false statement or to have knowingly or negligently falsified or allowed to be falsified any certificate, form, signed statement, application, report or certification of the correction of a violation required under the provisions of this code or of a rule of any agency, I may be barred from filing further applications or documents with the Department.

Name (please print)

Mark Warren

Signature

P.E. / R.A. Seal (apply seal, then sign and date over seal)

