




NYC DEPARTMENT OF ENVIRONMENTAL PROTECTION

Asbestos Control Program
59-17 Junction Boulevard, 8th Floor, Flushing, NY 11373

ASBESTOS ASSESSMENT REPORT



1. NYC DOB Job # (if applicable) _____ **Control Number: 1211148**

2. Premise No. 1589 Street Name Amsterdam avenue Borough Manhattan Zip 10031

3. AKA CCNY Harris Hall Type of Facility School BIN 1084082 Block 01957 Lot 0200
Dormitory Authority State of

4. Building Owner New York (DASNY) Address 515 Broadway

5. City Albany State NY Zip 12207 Contact Person Mark Moran

6. Tel. # (518) 257-3313 Fax # (518) 488-6811 Email mmoran@dasny.org

7. Description of the Entire Scope of Work

Interior, non-structural, renovations in the Cellar, and on the 4th, 2nd Floors including new mechanicals8. I, CHARLES COPPLE, have conducted an asbestos investigation on*Name of Certified Asbestos Investigator*10/15/2015 1:15PM-4:30PM*Date(s)*

in accordance

with Sections 1-16 and 1-28 of the NYC DEP Asbestos Control Program Rules and declare that at said facility address, the

- ☒ a. portion(s) of the premises affected by the work is free of asbestos containing material (ACM).
- ☐ b. premise (or portions thereof) affected by the work contains 10 square feet or less or 25 linear feet or less of ACM.
Specify locations in section 9: Note: This material must be abated as a minor project in accordance with relevant provisions of the DEP Asbestos Rules
- ☐ c. asbestos is present and will not be disturbed during construction activity. Specify the quantity and area where asbestos is present. Specify amount: _____ sq. ft _____ linear ft.
Specify locations (attach additional documents as necessary): _____

- ☐ d. entire building is free of asbestos containing material (ACM).



9. RESULTS OF ASBESTOS BUILDING SURVEY:


FLOOR	DESCRIBE SECTION OF FLOOR	ALL MATERIALS ASSUMED TO CONTAIN ACM AND/OR SAMPLED	NUMBER OF SAMPLES ANALYZED	ASBESTOS PRESENT	ASSUMED ACM
Cellar, 2nd & 4th	Classrooms, Offices & Labs	2x2 Acoustic Ceiling Tile	2	No	No
Cellar, 2nd & 4th	Classrooms, Offices & Labs	Black Vinyl Covebase	2	No	No
4th	Storage Room	2x4 Acoustic Ceiling Tile	2	No	No
4th	Storage Room	Brown Adhesive Dollops (Old)	2	No	No
4th	West Wing Offices	Yellow Carpet Adhesive	2	No	No
4th	South MER	Duct Seam Sealant	2	No	No

I hereby declare the information provided herein is true and complete

CHARLES COPPLE 10/26/2015 123655 8/9/2016
DEP Certified Asbestos Investigator's Signature Date Certificate Number Expiration Date

Tel. # (914) 654-0080 Fax # (914) 654-1332Email charlescopp@gmail.com

The investigator shall assume that some or all of the areas investigated contain ACM, and for each area that is not assumed to contain ACM, collect and submit for analysis bulk samples in accordance with §§ 1-36, 1-37, and 1-44 of the DEP Asbestos Rules and EPA publications 560/5-85-024 and 560/5-85-030a and 40 CFR 763.86

Is it a Build-It-Back project? ☐ Yes, App ID # _____ ☒ No

25222428



NYC DEPARTMENT OF ENVIRONMENTAL PROTECTION
Asbestos Control Program
59-17 Junction Boulevard, 8th Floor, Flushing, NY 11373
ASBESTOS ASSESSMENT REPORT



4th	South MER	Old Electrical Wire Jacket	2	No	No
Cellar, 2nd & 4th	Classrooms, Offices & Labs	Covebase Adhesive	2	No	No
Cellar, 2nd & 4th	Classrooms, Offices & Labs	Vinyl Floor Tile (5 types)	10	No	No
Cellar, 2nd & 4th	Classrooms, Offices & Labs	Yellow Adhesive with all Vinyl Floor Tile	2	No	No
Cellar, 2nd & 4th	Classrooms, Offices, Labs & MER	Wall & Ceiling Plaster (Rough & Finish Coats)	10	No	No
2nd	South Wing Lab	Finished Concrete Floor	3	No	No
Cellar, 2nd & 4th	Classrooms, Offices & Labs	Gypsum Wallboard	2	No	No
Cellar, 2nd & 4th	Classrooms, Offices & Labs	Joint Compound	2	No	No
4th	South MER	Spray-on Fireproofing on structural steel	3	No	No

10. ANALYTICAL LABORATORY:

NAME	ELAP # (NYS DOH CERTIFICATION)	DATE(S) SAMPLES ANALYZED
AmeriSci, NY	11480	10/14/2015
AmeriSci, NY	11480	10/15/2015

11. NYS DOL Asbestos Handling license # 28894 Company Name Applied Technology Services, Inc.


I hereby declare the information provided herein is true and complete

CHARLES COPPLE 10/26/2015 123655 8/9/2016
DEP Certified Asbestos Investigator's Signature Date Certificate Number Expiration Date

Tel. # (914) 654-0080 Fax # (914) 654-1332

Email charlescopple@gmail.com

The investigator shall assume that some or all of the areas investigated contain ACM, and for each area that is not assumed to contain ACM, collect and submit for analysis bulk samples in accordance with §§ 1-36, 1-37, and 1-44 of the DEP Asbestos Rules and EPA publications 560/5-85-024 and 560/5-85-030a and 40 CFR 763.86.



Is it a Build-It-Back project? ☐ Yes, App ID # _____ ☒ No



25222428