



NORTH

- NOTES
1. ALL BOILER ROOM WALLS, DOORS, CEILING, ETC TO HAVE EXISTING 2HR FIRE RATING
 2. EXISTING COMBUSTION AIR PROVIDED BY MECHANICAL SUPPLY FAN IN ACCORDANCE WITH NYC MECHANICAL CODE SECTION 706
 3. PROVIDE CLEARANCE FOR BOILER IN ACCORDANCE WITH NYC MECHANICAL CODE SECTION 1004

NOTE:

THIS PLAN IS APPROVED ONLY FOR WORK INDICATED ON THE APPLICATION SPECIFICATION SHEET, ALL OTHER MATTERS SHOWN ARE NOT TO BE RELIED UPON, OR TO BE CONSIDERED AS EITHER BEING APPROVED OR IN ACCORDANCE WITH APPLICABLE CODES.

THE DESIGN, DETAILS AND NOTES INCLUDED HEREIN ARE IN COMPLIANCE WITH LOCAL LAW 17/95 EARTHQUAKE CODE.

AS PER NYC BUILDING CODE SECTION 1613-1621 THE FOLLOWING EQUIPMENT SHALL BE DESIGNED, BRACED, ANCHORED, ETC. TO RESIST SEISMIC FORCES: EQUIPMENT AND MACHINERY INCLUDING SUCH ITEMS AS PUMPS FOR FIRE SPRINKLERS, MOTORS AND SWITCHGEAR FOR SPRINKLER RELATED TO LIFE SAFETY INCLUDING CONTROL PANELS, MAJOR CONDUIT, DUCTING & PIPING SERVING SUCH EQUIPMENT AND MACHINERY.

THE BOILER SYSTEMS REPRESENTED ON THIS PLAN ARE TO THE BEST OF MY KNOWLEDGE, BELIEF AND PROFESSIONAL JUDGMENT, IN COMPLIANCE WITH CURRENT NEW YORK ENERGY CONSERVATION CODE.

(SPS/IN/10/1)

NYC DOB APPLICATION NUMBER :		
NO.	REVISION COMMENT	DATE:
1	ISSUED TO DOB	9-28-16
2	ISSUE TO DOB, REV. BOILER	1-30-17
3	ISSUED TO DOB	3-17-17
4	ISSUED TO DOB, REV. PER OBJECTIONS	4-21-17
5	ISSUED TO DOB, REV. PER OBJECTIONS	5-26-17
6	PAA RE-ISSUED TO DOB	1-28-19
7	PAA RE-ISSUED TO DOB	10-29-19

CLIENT
Vermilyea West Associates,
LLC.
C/O Lemle & Wolff, Inc.
5925 Broadway
Bronx, NY 10463
P: 718.884.7676
F: 718.884.5300

MECH. / ELEC. ENGINEERS

DI BARI
ENGINEERING, P.C.
99 MAIN STREET
DOBBS FERRY, NY 10522
TE: 914-478-0765 914-478-1234
WWW.DIBARI.US

STRUCTURAL ENGINEERS

**DESIGN
+
AIDD**
ARCHITECTURE, DPC
508 West 26th Street, Suite 5C
New York, New York 10001
P: 212.255.5056
F: 212.255.4931 ©

428 WEST 204TH STREET NEW YORK, NEW YORK 10034	Drawing Title: BOILER FILING CELLAR FLOOR PLAN	Drawn By:
		Checked By:
		Issue Date:
		Plot Date:
		Scale:
		Job:
		Sheet: M954



Drawing No.:
 BL-101.01

3 OF 4

