




NYC DEPARTMENT OF ENVIRO

Asbestos Control Program
59-17 Junction Boulevard, 8th Floor, Flushing, NY 11373

ASBESTOS ASSESSMENT REPORT



1. NYC DOB Job # (if applicable) _____ **Control Number: 1480383**
2. Premise No. 600 Street Name West 142nd Street Borough Manhattan Zip 10031
3. AKA _____ Type of Facility Residence BIN 1062331 Block 02088 Lot 0098
4. Building Owner 142 Broadway Associates, LLC Address 888 7th Avenue, Suite 2400
5. City New York State NY Zip 10019 Contact Person Darin Goldstein
6. Tel. # (212) 660-1200 Fax # _____ Email _____
7. Description of the Entire Scope of Work
Removal and installation of interior wall, relocation of plumbing fixtures at apartment 64 at 6th floor. All interior along with plumbing fixtures are gutted with metal studs exposed.

8. I, JAMES PARK, have conducted an asbestos investigation on

Name of Certified Asbestos Investigator

09/20/2018 4:45PM-5:45PM

Date(s)

in accordance

with Sections 1-16 and 1-28 of the NYC DEP Asbestos Control Program Rules and declare that at said facility address, the

- ☒ a. portion(s) of the premises affected by the work is free of asbestos containing material (ACM).
- ☐ b. premise (or portions thereof) affected by the work contains 10 square feet or less or 25 linear feet or less of ACM.
Specify locations in section 9: Note. This material must be abated as a minor project in accordance with relevant provisions of the DEP Asbestos Rules.
- ☐ c. asbestos is present and will not be disturbed during construction activity Specify the quantity and area where asbestos is present. Specify amount: _____ sq. ft _____ linear ft.
Specify locations (attach additional documents as necessary): _____

- ☐ d. entire building is free of asbestos containing material (ACM).

9. RESULTS OF ASBESTOS BUILDING SURVEY:

LOCATION	FLOOR NUMBER	DESCRIBE SECTION OF FLOOR	ALL MATERIALS ASSUMED TO CONTAIN ACM AND/OR SAMPLED	NUMBER OF SAMPLES ANALYZED	ASBESTOS PRESENT	ASSUMED ACM
Building Floors	6 to 6	Apt.# 64 - Gutted Ceiling	Wood Joist	0	No	
Building Floors	6 to 6	Apt.# 64 - Gutted Wall Behind New Metal Studs	Plaster	3	No	
Building Floors	6 to 6	Apt.# 64 - Gutted Wall Behind New Metal Studs	Brick Mortar	3	No	
Building Floors	6 to 6	Apt.# 64 - Gutted Wall at Bathroom	Ceramic Wall Tile Debris	3	No	

I hereby declare the information provided herein is true and complete

JAMES PARK 9/30/2018 117762 5/21/2020
DEP Certified Asbestos Investigator's Signature Date Certificate Number Expiration Date

Tel. # (718) 607-6625 Fax # _____

Email info@arinspectionnyc.com

The investigator shall assume that some or all of the areas investigated contain ACM, and for each area that is not assumed to contain ACM, collect and submit for analysis bulk samples in accordance with §§ 1-36, 1-37, and 1-44 of the DEP Asbestos Rules and EPA publications 560/5-85-024 and 560/5-85-030a and 40 CFR 763.86, 40 CFR 763.80, 40 CFR 763.85

SEAL OF THE
NYC DEP
CERTIFIED
ASBESTOS
INVESTIGATOR



Is it a Build-It-Back project? ☐ Yes, App ID # _____ ☒ No



25500931



NYC DEPARTMENT OF ENVIRONMENTAL PROTECTION
Asbestos Control Program
59-17 Junction Boulevard, 8th Floor, Flushing, NY 11373
ASBESTOS ASSESSMENT REPORT



Building Floors	6 to 6	Apt.# 64 - Floor	Plywood	0	No
-----------------	--------	------------------	---------	---	----

10. ANALYTICAL LABORATORY:

NAME	ELAP # (NYS DOH CERTIFICATION)	DATE(S) SAMPLES ANALYZED
ALAC Analytical Labs	11605	9/22/2018

11. NYS DOL Asbestos Handling license # 58309 Company Name Asbestos Rescue LLC


I hereby declare the information provided herein is true and complete

JAMES PARK 9/30/2018 117762 5/21/2020
DEP Certified Asbestos Investigator's Signature Date Certificate Number Expiration Date

Tel. # (718) 607-6625 Fax # _____

Email info@arinspectionnyc.com

The investigator shall assume that some or all of the areas investigated contain ACM, and for each area that is not assumed to contain ACM, collect and submit for analysis bulk samples in accordance with §§ 1-36, 1-37, and 1-44 of the DEP Asbestos Rules and EPA publications 560/5-85-024 and 560/5-85-030a and 40 CFR 763.86, 40 CFR 763.80, 40 CFR 763.85.



Is it a Build-It-Back project? ☐ Yes, App ID # _____ ☒ No



25500931