



Buildings

OP-98 Notice/Results—Self-Certification of Plumbing, Sprinkler, Standpipe Inspection(s) & Test(s)

A copy of this completed notice must be retained for re-submission with results.



1 Permit No. 140142370		Document No. 01		Permit Type (check one only): ☒ PL ☐ SP ☐ SD ☐ LAA	
Borough	Manhattan	Block	2174	Lot	88
House No	112				
Street Name	Nagle Ave				
2 Permit Applicant		E-Mail: MPSPLG@YAHOO.COM		Business Phone (718) 353-9696	
Last Name MA		First Name LI KONG		M.I.	
Address 36-05c college point blv		City FLUSHING		State NY ZIP 11354	
License No. 2039		☒ LMP ☐ LFSC			
3 Inspection Data Inspection/test scheduled for: 03/11/14 (mmddyy) Time: ☐ 8:00am ☐ 8:30 ☐ 9:00 ☐ 9:30 ☐ 10:00 ☐ 10:30 ☐ 11:00 ☐ 11:30 ☐ 12:30pm					
Apts and Floors: Cellar ☒ 100pm ☐ 1:30 ☐ 2:00 ☐ 2:30 ☐ 3:00 Meeting Location: IN FRONT OF BUILDING					

4 Notice/Result (Select one: PL, SP, SD only)																												
Systems: Inspections			Plumbing (PL)						Systems: Inspections			Sprinkler (SP)						Systems: Inspections			Standpipe (SD)							
			Underground		Roughing		Finish					Underground		Roughing		Finish					Underground		Roughing		Finish			
			Notice	Results	Notice	Results	Notice	Results				Notice	Results	Notice	Results	Notice	Results				Notice	Results	Notice	Results	Notice	Results		
			Pass	Fail	Pass	Fail	Pass	Fail				Pass	Fail	Pass	Fail	Pass	Fail				Pass	Fail	Pass	Fail	Pass	Fail		
Sprinkler - PL									Sprinkler - SP									Fire Standpipe - SD										
Water/Sanitary - PL																		Alarm Sys 64/09										
Storm - PL																												
Gas - PL																												
Medical Gas - PL																												
Tests			Notice	Results							Tests	Notice	Results							Tests	Notice	Results						
Hydrostatic - PL									Hydrostatic - SP									Hydrostatic - SD										
Water - Sanitary									Dry Pipe Valve									Fire Pump										
Pressure - Water									Booster Pump																			
Water Storm																												
Gas																												
Medical Gas																												

Gas Tested at psi: ☒ 3 psi ☐ 50 psi ☐ 90 psi ☐ 100 psi

Additional Information/Comments: Gas authorization required. Installed Dual Fuel system, EX'G boiler: Federal

☐ Submitted with minor variations, described here: Input: 1680,000BTU/HR, Output: 1339,000BTU/HR

☐ Legalization ☐ Gas to Gas Appliance Direct Replacement ☐ Remove/Cap ☐ Detention ☐ Drywell/Retention

5 Gas Meters/Risers Data (Check all applicable to this inspection. Include gas usages for each listed meter(s)/riser(s))		☒ Gas requested for listed meters and risers	
No. of Meters: 1	Location(s) (Floor/Apt.): Cellar	No. of Risers: 1	Location(s) (Floor/Apt.): Cellar
☐ Welded Gas Piping			
Gas usage: ☒ Heat ☐ Boiler Pilot for oil burner ☐ Water Heater ☐ Dryer			
☐ Cooking ☒ Tankless Coil ☐ HVAC ☐ Fire Place ☐ Other (describe):			
6 Certifying Applicant		E-Mail: MPSPLG@YAHOO.COM	
Last Name MA		First Name LI KONG	
Address 36-05c college point bl. City FLUSHING		State NY ZIP 11354 License No. 2039	
☒ LMP ☐ LFSC ☐ P.E. ☐ R.A.			

7 Applicant Statements and Signatures ☐ All Comments resolved, review for sign-off ☐ All required back-up documents attached			
I certify the statements herein are correct and comply with the NYC Building code. I meet the requirements of the NYC Building code as they relate to the experience requirements set forth for gas tests. I realize falsification of any statement is a misdemeanor under §28-211.1 of the Administrative code punishable by a fine or imprisonment or both and may result in removal from participation in the self-certification program and/or disciplinary action by the Licensed Master Plumber or Licensed Fire Suppression Piping Contractor License Board.			
Print Name of Certifying Applicant LI KONG MA		SEAL	
Signature		Signature	
Date 03/11/14		Date 03/11/14	

Reviewed by: [Signature] Date: 4/2 Entered by: [Signature] R.S.O. by: [Signature] S/O by: [Signature]