

1133-6th AVENUE NEW YORK, NY:
2011 ENGERGY CODE COMPLIANCE

ENERGY ANALYSIS
ITEM DESCRIPTION

WATER COOLED UNIT
AS PER TABLE 6.8.1A
<135,000 BTUH
>135,000 BTUH

AS PER ASHRAE STD 90.1-2007
CODE PRESCRIPTIVE VALUE
EER MINIMUM

11.3
10.8

PROPOSED DESIGN VALUE
SEER MINIMUM

11.3
11.0

