



NYC DEPARTMENT OF ENVIRONMENTAL PROTECTION
Asbestos Control Program
 59-17 Junction Boulevard, 8th Floor, Flushing, NY 11373
ASBESTOS ASSESSMENT REPORT



1. NYC DOB Job # (if applicable) _____ **Control Number: 1133228**

2. Premise No. 2120 Street Name Madison Avenue Borough Manhattan Zip 10037
 Bldg# 11 - at Lincoln

3. AKA Houses Type of Facility Residence BIN 1081116 Block 01757 Lot 0001

4. Building Owner New York City Housing Authority (NYCHA) Address 90 Church Street, 11th Floor

5. City Manhattan State NY Zip 10007 Contact Person Richard Morrison

6. Tel. # (212) 306-3154 Fax # (212) 306-5118 Email Richard.Morrison@nycha.nyc.gov

7. Description of the Entire Scope of Work
 REPLACEMENT OF A,B,C,D,E&J-LINE GAS RISERS AND OVERHEAD PIPING FROM CELLAR TO 14TH FLOOR. PIPES TO BE INSTALLED IN EXISTING PENETRATIONS FROM 3RD TO 14TH FLOOR AND IN NEW PENETRATIONS FROM CELLAR TO 2ND FLOOR.

8. I, MIKHAIL POPOVETSKIY, have conducted an asbestos investigation on
01/11/2014 in accordance
 Date(s)
 with Sections 1-16 and 1-28 of the NYC DEP Asbestos Control Program Rules and declare that at said facility address, the

☐ a. portion(s) of the premises affected by the work is free of asbestos containing material (ACM).

☒ b. premise (or portions thereof) affected by the work contains 10 square feet or less or 25 linear feet or less of ACM.
 Specify locations in section 9: Note: This material must be abated as a minor project in accordance with relevant provisions of the DEP Asbestos Rules.

☒ c. asbestos is present and will not be disturbed during construction activity. Specify the quantity and area where asbestos is present. Specify amount: 72 sq. ft 30 linear ft.
 Specify locations (attach additional documents as necessary):
1.3rd to 14th Floor A,B,C,D,E&J-Line Kitchen Flooring - at Gas Risers/Floor Penetrations 2.1st Floor Day Care Center - Piping Insulation Located in the Soffits Along with the Gas Risers.

☐ d. entire building is free of asbestos containing material (ACM).

9. RESULTS OF ASBESTOS BUILDING SURVEY:

FLOOR	DESCRIBE SECTION OF FLOOR	ALL MATERIALS ASSUMED TO CONTAIN ACM AND/OR SAMPLED	NUMBER OF SAMPLES ANALYZED	ASBESTOS PRESENT	ASSUMED ACM
2nd to 13th Floor	A,B,C,D,E&J-Line Kitchens - at Gas Risers/Ceiling Penetrations	Pipe Penetration Packing	45	No	No
1st and 2nd Floor	A,B,C,D,E&J-Line Apartments and Day Care Center - at Existing Gas Piping Locations & Penetrations	Wall & Soffit Plaster, Ceiling and Soffit Popcorn Coating	22	No	No

I hereby declare the information provided herein is true and complete

Mikhail Popovetskiy
 MIKHAIL POPOVETSKIY 6/26/2014 113601 4/6/2015
 DEP Certified Asbestos Investigator's Signature Date Certificate Number Expiration Date
 Email mikhail.popovetskiy@nycha.nyc.gov
 Tel. # (718) 707-5223 Fax # (718) 707-5255



The investigator shall assume that some or all of the areas investigated contain ACM, and for each area that is not assumed to contain ACM, collect and submit for analysis bulk samples in accordance with §§ 1-36, 1-37, and 1-44 of the DEP Asbestos Rules and EPA publications 560/5-85-024 and 560/5-85-030a and 40 CFR 763.86.

SEAL OF THE NYC DEP CERTIFIED ASBESTOS INVESTIGATOR



25139185



NYC DEPARTMENT OF ENVIRONMENTAL PROTECTION

Asbestos Control Program
59-17 Junction Boulevard, 8th Floor, Flushing, NY 11373

ASBESTOS ASSESSMENT REPORT

RECEIVED

6/26/2014

DEP
ASBESTOS CONTROL
PROGRAM

FEE EXEMPT

1st and 2nd Floor	A,B,C,D,E&J-Line Apartments and Day Care Center - at Gas Risers/Floor Penetrations	Floor Tiles and Mastic (Impacted)	0	Yes	Yes
3rd to 14th Floor	A,B,C,D,E&J-Line Kitchens - at Gas Risers/Floor Penetrations	Floor Tiles and Mastic (Not Impacted)	0	Yes	Yes
Cellar	Areas of A,B,C,D,E&J-Line Gas Risers and Overhead Piping Locations and Penetrations	Ceiling Slabs - Concrete, Walls - Cinderblock/Concrete, Piping Insulation in Work Areas - Fiberglass (Non-Asbestos Suspected Materials)	0	No	No
1st Floor	Day Care Center Soffits - at A,B & J-Gas Risers Locations	Piping Insulation	0	Yes	Yes

10. ANALYTICAL LABORATORY:

NAME	ELAP # (NYS DOH CERTIFICATION)	DATE(S) SAMPLES ANALYZED
ATC Associates Inc	10879	1/15/2014
ATC Associates Inc	10879	1/23/2014

11. NYS DOL Asbestos Handling license # 29024 Company Name New York City Housing Authority

I hereby declare the information provided herein is true and complete

Mikhail Popovetsky

MIKHAIL POPOVETSKIY

6/26/2014

113601

4/6/2015

DEP Certified Asbestos Investigator's Signature

Date

Certificate Number

Expiration Date

mikhail.popovetsky@nycha.

Tel. # (718) 707-5223

Fax # (718) 707-5255

Email nyc.gov

The investigator shall assume that some or all of the areas investigated contain ACM, and for each area that is not assumed to contain ACM, collect and submit for analysis bulk samples in accordance with §§ 1-36, 1-37, and 1-44 of the DEP Asbestos Rules and EPA publications 560/5-85-024 and 560/5-85-030a and 40 CFR 763.86.

SEAL
OF THE
NYC DEP
CERTIFIED
ASBESTOS
INVESTIGATOR

25139185