




AI1: Additional Information

Must be typewritten.



140500009

Page number 01 of 01 BIS Document No. 01

1 Location and Job Information Required for all applications.

House No(s) 270 Street Name WEST 132 STREET

Borough MANHATTAN Block 1937 Lot 58 BIN 1058735 CB No. 110

2 Revisions to Plans/Drawings Required whenever updating plans. All revisions for each page must be clearly described in section 3.

Submission is part of a Post Approval Amendment (PAA)? ☐ Yes PW1 required ☒ No Indicate all actions for this submission:

Action	Original/New/ Omit Page ID	Superseding Page ID	Action	Original/New/ Omit Page ID	Superseding Page ID	Action	Original/New/ Omit Page ID	Superseding Page ID	Action	Original/New/ Omit Page ID	Superseding Page ID

For "Action" use "N" for new page, "S" for superseding page, "O" for omitting page. Is this section continued on additional AI1 forms? ☐ Yes ☒ No

3 Additional Information Required for all applications.

Herewith submit AI1 to resolve objections for ALT-2 JOB# 140500009:

-Objection:

Per §28-112.3. Values shown on PW3(\$48,455.00) is below reasonable valuation of construction values by more than 10% of DOB values by cost guide. The PW3 need to upload to comply with as stated above.

-Response:

Revised PW3 has been uploaded into e-submit folder.

-Objection:

Asbestos Abatement Compliance: The scope of work is not exempted as per DEP Asbestos Exemptions memo dated June 23, 2010 and the property was not built on after on or after April 1, 1987, in accordance with §28-106.1. Need to Make a dear change at PW1 to comply with Asbestos Abatement Compliance also upload documents accordingly.

-Response:

PW1 has been corrected to comply with Asbestos Abatement Compliance in BIS system.

-Objection:

AC 28-104.7.1: Hydraulic flow calculation documents need to be signed and sealed.(each page)

-Response:

Signed and sealed every page of the Hydraulic calculation and uploaded to e-submit.

-Objection:

AC:128-104.7.1 Clarify anti-freeze for dry sp head.

-Response:

No anti-freeze is used.

The dry sprinkler head is standard dry head, Viking, #VK182.

Falsification of any statement is a misdemeanor and is punishable by a fine or imprisonment, or both. It is unlawful to give to a city employee, or for a city employee to accept, any benefit, monetary or otherwise, either as a gratuity for properly performing the job or in exchange for special consideration. Violation is punishable by imprisonment or fine or both. I understand that if I am found after hearing to have knowingly or negligently made a false statement or to have knowingly or negligently falsified or allowed to be falsified any certificate, form, signed statement, application, report or certification of the correction of a violation required under the provisions of this code or of a rule of any agency, I may be barred from filing further applications or documents with the Department.

Name (please print)

Signature

P.E. / R.A. Seal (apply seal, then sign and date over seal)

Date



6-8-16