




AI1: Additional Information

Must be typewritten.



Page number 1 of 1 BIS Document No. 02

1 Location and Job Information Required for all applications.

House No(s) 156 Street Name E 39TH STREET
 Borough MANHATTAN Block 894 Lot 50 BIN 1082112 CB No. 106

2 Revisions to Plans/Drawings Required whenever updating plans. All revisions for each page must be clearly described in section 3.

Submission is part of a Post Approval Amendment (PAA)? ☒ Yes *PW1 required* ☐ No Indicate all actions for this submission:

Action	Original/New/ Omit Page ID	Superseding Page ID	Action	Original/New/ Omit Page ID	Superseding Page ID	Action	Original/New/ Omit Page ID	Superseding Page ID	Action	Original/New/ Omit Page ID	Superseding Page ID
S	A-001.00	A-001.01									
S	A-002.00	A-002.01									
S	A-003.00	A-003.01									

For "Action" use "N" for new page, "S" for superseding page, "O" for omitting page. Is this section continued on additional AI1 forms? ☐ Yes ☒ No

3 Additional Information Required for all applications.

Below are the responses to the examiner's objections

1) Please indicate property line at plot plan to make consistent with this diagram.

Response: The plot plan is consistent with the diagram.

2) Please mark the work area under this application and then cloud.

Response: The work area is the hood only (exhaust system and the make up air are existing to remain).

We propose to replace existing hood with smaller size hood for the pizza oven.

3) Demonstrate compliance with MC-401.4: Intake opening location. Please indicate on plan showing all dimension to indicate compliance. Also demonstrate compliance with MC-401.4.1 Required dampers in intake openings (provide damper details), MC-401.5 Intake opening protection. At TR8 check for Shutoff Damper inspection Demonstrate compliance with MC-401.4: Intake opening location. Please indicate on plan showing all dimension to indicate compliance.

Response: The dimensions are shown on plans, the existing make up air unit is existing and is running to the roof. There is no fire damper will be needed.

Falsification of any statement is a misdemeanor and is punishable by a fine or imprisonment, or both. It is unlawful to give to a city employee, or for a city employee to accept, any benefit, monetary or otherwise, either as a gratuity for properly performing the job or in exchange for special consideration. Violation is punishable by imprisonment or fine or both. I understand that if I am found after hearing to have knowingly or negligently made a false statement or to have knowingly or negligently falsified or allowed to be falsified any certificate, form, signed statement, application, report or certification of the correction of a violation required under the provisions of this code or of a rule of any agency, I may be barred from filing further applications or documents with the Department.

Name (please print) SAJJAD AKBAR, R.A.
 Signature [Signature] Date 6/8/17
 P.E. / R.A. Seal (apply seal, then sign and date over seal)

