



Date: 7/30/2020

BLOCK: 1080
LOT (S): 102

Vincent Sapienza
Commissioner

Anastasios Gerorgelis, P.E.
Deputy Commissioner
Bureau of Water &
Sewer Operations

connections@dep.nyc.gov

59-17 Junction Boulevard
Flushing, NY 11373

To Whom It May Concern:

This is to certify that the records of this bureau show that on 07/22/20

12" x 4" Wet Connection with 6" Ductile Iron Pipe for Fire Water Service

was installed for:

premises at 726-728 11 Ave (AKA: 553 W. 51 St)(CUT on: W. 51 St.)

Borough of Manhattan by plumber K. Kucic

under permit no. 898144 and that the installation passes inspection

by this department on that date.

Very truly yours,

Muhammad E Hossain, PhD, PE
Chief, Connections



Date: 2/13/2020

BLOCK: 1080

LOT (S): 102

Vincent Sapienza
Commissioner

To Whom It May Concern:

Anastasios Gerorgelis, P.E.
Deputy Commissioner
Bureau of Water &
Sewer Operations

This is to certify that the records of this bureau show that on 02/05/20

12" x 3" Wet Connection with 3" Ductile Iron Pipe for Domestic Water Service

connections@dep.nyc.gov

was installed for:

59-17 Junction Boulevard
Flushing, NY 11373

premises at 726-728 11 Ave (CUT on: 11 Ave)

Borough of Manhattan by plumber Kuzma Kucic

under permit no. 897155 and that the installation passes inspection

by this department on that date.

Very truly yours,

Muhammad E Hossain, PhD, PE
Chief, Connections



Date: 2/13/2020

BLOCK: 1080

LOT (S): 102

Vincent Sapienza
Commissioner

To Whom It May Concern:

Anastasios Gerorgelis, P.E.
Deputy Commissioner
Bureau of Water &
Sewer Operations

This is to certify that the records of this bureau show that on 02/05/20

12" x 4" Wet Connection with 6" Ductile Iron Pipe for Fire Water Service

connections@dep.nyc.gov

was installed for:

59-17 Junction Boulevard
Flushing, NY 11373

premises at 726-728 11 Ave (CUT on: 11 Ave)

Borough of Manhattan by plumber Kuzma Kucic

under permit no. 897156 and that the installation passes inspection

by this department on that date.

Very truly yours,

Muhammad E Hossain, PhD, PE
Chief, Connections

THE CITY OF NEW YORK
DEPARTMENT OF ENVIRONMENTAL PROTECTION
BUREAU OF SEWERS

BOROUGH OF MN

CERTIFICATE OF INSPECTION - NEW SEWER HOUSE CONNECTION

The below described sewer house connection has been laid from the property line to the existing sewer at premises:

H.Q.# 121203931 Block 1080 Lot 102
P.R.A.
Under Permit Number 892336 Issued 11/26, 2020
Premises 726-728 11 AVE
house number and street
Located _____ wide, _____ feet _____ of _____
Owner Clinton H.D.F.C
Plumber Kuzma Kucic
Size and type of pipe laid 8" DIP Combined
Connected to 48X32 Sewer laid in
size, type
11th AVE
street, avenue

I hereby Certify that I made the inspection of the Sewer House Connection described above and that all work done under this permit has been properly completed in accordance with existing ordinances, rule and regulations.

Name Ch. Reynolds / cell. Pacheco / A. Morales
Inspector-Division-Sewer Construction
Signed [Signature] Date: 1-31-20
Noted M. Horn Date: 02/03/2020
Engineer in Charge


PENALTY FOR FALSIFICATION:

Falsification of any statement made herein is an offense punishable by a fine of imprisonment of both (N.Y.C. Administrative Code. Section 1151-90)

Copies to: Borough Superintendent, Department of Buildings
Borough Office, Bureau of Water Register
Sewer Regulation and Control Section
File original in Borough Office, Sewer Regulation & Control

726-728	11 Ave	1080	102
house number	street name	block	lot

1. Was connection extended from curb connection? ☐ yes, ☒ no
2. Was the connection placed on earth, stone or crushed rock, concrete cradle, concrete encasement or reinforced concrete encasement? (circle one)
3. Was connection made to existing spur or riser or cut in? (circle one)
4. If connection was "cut in", was saddle or Dutchman used? (if so, circle)
5. Length, size and material of new connection 49' 0" 8" DIP
6. Depth of connection at curb line is 9' 6" feet.
7. All work was exposed and inspected.



11 Ave
curb line

date 1-31-20

signed

[Signature] / *am*