



Plumbing Division
Sprinkler Inspection Report



Premises 112 HENWOOD PLACE Borough BRONX Date 08/11/2009
Approved Plan # 210009541 Stories 9 Feet 110 FT When Installed 080109
Construction BRICK Occupancy RESIDENTIAL No. of water supplies 1 Area 29,434 SQ FT
Wet or Dry WET

Supply: City Water Connection Size 6" Fed 2 ways YES
Curb or P.I. Valve CURB Name & size of meter 6" DDCVW/NEPTUNE 3/4" BYPASS METER
Valves sealed open YES Lbs. Pressure 65

Gravity Tank Capacity NONE Heated Height over top sprinkler line
Size fill line Size Overflow Emergency Drain Valve
Type and Size Tank piping brass Exposed piping weatherproofed
Ladder secured Location tank check and control valve
Valves sealed open No. Fill Pumps Size Type
Capacity in gallons How operated

Pressure Tank Capacity NONE Tank House Heated Size Fill Line
Emergency Drain Valve Type and Size Air Pressure
Water Level Location tank check and control valves
Control valves sealed open

Risers No. 1 Size dead risers 0 Size live risers 6"
Size drain risers 2" Floor control valves YES Sealed open NO
Main Drain YES Size 2" Location inspectors Test valve EACH FLOOR STAIRWELL
Exposed Piping or Heads NO Location How protected
No. Cold Weather Valves NONE Location App'd signs YES

No. Dry Valves NONE Name Type Water Pressure
Air Pressure Dry Valve room heated
No. of heads controlled by each dry pipe valve

No. Alarm Valves NONE Size and type Local Supervisory
High-Low Gravity High-Low Pressure Flow Alarm

Fire Pumps: Name NONE Type Capacity in Gallons
Or
Booster Pumps: Checked Draws from Size of suction line
Size of discharge line How operated Supervisory
Adequate pressure in system

No. Siamese connections YES Size 6 X 3 X 3 App'd Type YES
Location FRONT BLDG Signs YES Type of drips BALL
Caps painted green YES
Is every square foot of the building sprinklered YES
If not, portion sprinklered
Extra heads & wrench provided YES Painted or corroded heads NONE

Is installation as per app'd plan YES As per Fire Dept. order
Entire system tested at 200 p.s.i. YES Result SATISFACTORY
Certificate of Fitness required

Recommendations:

OWNER'S NAME AND ADDRESS	CONTRACTOR'S NAME AND ADDRESS
WALTON-HENWOOD HSG DEV 1022 REV JAMES POLITE AVE BRONX, ny 10459	TRICOUNTY FIRE EQUIPMENT 436a BEACH 129TH ST BELLE HARBOR, NY 11694

Inspector (sign) Neil Metz Inspector (print) Neil Metz

Test Listed
By

Report to: Div. Of Fire Prevention,
Fire Department