



Buildings

OP-98 Notice/Results—Self-Certification of Plumbing, Sprinkler, Standpipe Inspection(s) & Test(s)

A copy of this completed notice must be retained for re-submission with results.



DEPT.BLDGS

210010833

Job Number

SC090909006

Scan Code

1 Permit No. 210010833		Document No. 01		Permit Type (check one only): ☐ PL ☒ SP ☐ SD ☐ LAA	
Borough Bronx		Block 4340		Lot 37	
House No 2330		Street Name Bronx Park East			
2 Permit Applicant E-Mail: amkay@aol.com					
Business Phone (212) 828-7565		Fax No. (212) 828-7566			
Last Name Huertas		First Name Jorge		M.I. L	
Business Name Amkay plumbing & Heating Corp.					
Address 420-B East 111 Street		City Manhattan		State NY	
ZIP 10029		License No. 420		☐ LMP ☒ LFSC	
3 Inspection Data Inspection/test scheduled for: 08/31/09 (mmddyy) Time: ☐ 8:00am ☐ 8:30 ☐ 9:00 ☒ 9:30 ☐ 10:00 ☐ 10:30 ☐ 11:00 ☐ 11:30 ☐ 12:30pm					
Apts and Floors: Cel, 1,2,3,4,5,6,7, roof ☐ 1:00pm ☐ 1:30 ☐ 2:00 ☐ 2:30 ☐ 3:00 Meeting Location: Front of building					

4 Notice/Result (Select one: PL, SP, SD only)																	
Systems: Inspections						Systems: Inspections						Systems: Inspections					
Plumbing (PL)						Sprinkler (SP)						Standpipe (SD)					
Underground		Roughing		Finish		Underground		Roughing		Finish		Underground		Roughing		Finish	
Notice	Results	Notice	Results	Notice	Results	Notice	Results	Notice	Results	Notice	Results	Notice	Results	Notice	Results	Notice	Results
	Pass Fail		Pass Fail		Pass Fail		Pass Fail		Pass Fail		Pass Fail		Pass Fail		Pass Fail		Pass Fail
Sprinkler - PL	☐	☐	☐	☐	☐	☐	☐	☐	☐	☐	☐	☐	☐	☐	☐	☐	☐
Water/Sanitary - PL	☐	☐	☐	☐	☐	☐	☐	☐	☐	☐	☐	☐	☐	☐	☐	☐	☐
Storm - PL	☐	☐	☐	☐	☐	☐	☐	☐	☐	☐	☐	☐	☐	☐	☐	☐	☐
Gas - PL	☐	☐	☐	☐	☐	☐	☐	☐	☐	☐	☐	☐	☐	☐	☐	☐	☐
Medical Gas - PL	☐	☐	☐	☐	☐	☐	☐	☐	☐	☐	☐	☐	☐	☐	☐	☐	☐
Tests						Tests						Tests					
Notice		Results				Notice		Results				Notice		Results			
	Pass Fail		Pass Fail				Pass Fail		Pass Fail				Pass Fail		Pass Fail		
Hydrostatic - PL	☐	☐	☐	☐	☐		☒	☐	☐	☐	☐		☐	☐	☐	☐	☐
Water - Sanitary	☐	☐	☐	☐	☐		☐	☐	☐	☐	☐		☐	☐	☐	☐	☐
Pressure - Water	☐	☐	☐	☐	☐		☐	☐	☐	☐	☐		☐	☐	☐	☐	☐
Water Storm	☐	☐	☐	☐	☐		☐	☐	☐	☐	☐		☐	☐	☐	☐	☐
Gas	☐	☐	☐	☐	☐		☐	☐	☐	☐	☐		☐	☐	☐	☐	☐
Medical Gas	☐	☐	☐	☐	☐		☐	☐	☐	☐	☐		☐	☐	☐	☐	☐
Gas Tested at psi																	
☐ 3 psi ☐ 50 psi																	
☐ 90 psi ☐ 100 psi																	

Additional Information/Comments:

☐ Submitted with minor variations, described here:

☐ Legalization ☐ Gas to Gas Appliance Direct Replacement ☐ Remove/Cap ☐ Detention ☐ Drywell/Retention

5 Gas Meters/Risers Data (Check all applicable to this inspection. Include gas usages for each listed meter(s)/riser(s)) ☐ Gas requested for listed meters and risers

No. of Meters: Location(s) (Floor/Apt. for this inspection): No. of Risers: Location(s) (Floor/Apt. for this inspection):

Gas usage: ☐ Heat ☐ Boiler Pilot for oil burner ☐ Water Heater ☐ Dryer

☐ Cooking ☐ Tankless Coil ☐ HVAC ☐ Fire Place ☐ Other (describe):

6 Certifying Applicant E-Mail: amkay@aol.com Business Phone (212) 828-7565 Fax No. (212) 828-7566

Last Name **Huertas** First Name **Jorge** M.I. **L** Business Name **Amkay Plumbing & Heating Corp.**

Address **420-B East 111 Street** City **Manhattan** State **NY** ZIP **10029** License No. **420** ☐ LMP ☒ LFSC ☐ P.E. ☐ R.A.

7 Applicant Statements and Signatures ☒ All Comments resolved, review for sign-off ☒ All required back-up documents attached

I certify the statements herein are correct and comply with the NYC Building code. I meet the requirements of the NYC Building code as they relate to the experience requirements set forth for gas tests. I realize falsification of any statement is a misdemeanor under §28-211.1 of the Administrative code punishable by a fine or imprisonment or both and may result in removal from participation in the self-certification program and/or disciplinary action by the Licensed Master Plumber or Licensed Fire Suppression Piping Contractor License Board.

Print Name of Certifying Applicant Jorge L Huertas	SEAL	Print Name of Permit Applicant or Alternative licensee from same firm (LMP/LFSC) Jorge L. Huertas	SEAL
Signature <i>Jorge Huertas</i>		Signature <i>Jorge Huertas</i>	
Date Sept 8th 2009		Date Sept 8th 2009	

Reviewed by: *af*, Date: **9.14.09**, Entered by: *af*, R.S.O. by: *af*, S/O by: _____



**Plumbing Division
Standpipe Inspection Report**

Date 08/31/2009

Premises 2330 Bronx Park East Borough Bronx When Installed 2009
Approved Plan # 210010833 Stories 7 Feet 67 Area Entire Building
Construction Brick Occupancy Residential No. of water supplies 1

Supply: City connection ☒ Size ☒ Control valve ☒ Curb valve ☒ Check valve ☒

Pressure or Gravity tank Capacity N/A Height above top outlet N/A
House supply taken from tank N/A Reserve for standpipe N/A Separate filling line N/A
Size N/A Size of overflow N/A Tank heated N/A Size of heating pipes N/A
Emergency valve N/A Size N/A Easily accessible N/A Exposed piping properly N/A
Weather-proofed N/A Iron ladder to tank N/A Properly secured N/A Filling pump N/A
Type N/A Size N/A Capacity in gallons N/A Automatic N/A

Intermediate tank Location N/A Reserve for Standpipe N/A
Height above outlet next below N/A Separate filling line N/A Size N/A
Size of overflow N/A Tank Heated N/A Emergency valve N/A Size N/A
Filling pump N/A Type N/A Size N/A Capacity in gallons N/A Automatic N/A

High & Low Alarms Electrical _____ Mechanical _____

Control Valve Location front of build Type OS&Y Locked Open Yes

Risers: Number 1 Size 6" Location staircase Protected Yes
Cross Connection N/A Top or Bottom N/A Size N/A

Hose Outlet Valves Size 2 1/2" Hgt. Above floor 4-8" Type of Valve angel
Hose yes Size 1 1/2" In Cabinets no/Rack In 50' lengths yes Sufficient Yes
Nozzle Yes Size 1 1/2"

Pressure reducing valves N/A Location N/A Type N/A
Set at what pressure N/A

Fire pump N/A Type N/A Size N/A Capacity in gallons N/A
Properly checked N/A Fire pump supply N/A Telephone system N/A

Siamese connections 1 Number 1 Size 5x3x3
Location grad level Approved type yes

Is all piping properly braced yes Give size and branch lines from riser to outlets 6 X 2 1/2"
Is building sprinklered yes If so, is there any connection between standpipe and sprinkler yes

Entire system at minimum of 300lbs yes Result pass
Performance test on standpipe fire pump N/A Result N/A
All required signs posted yes

Recommendations: _____

Inspector (print) Jorge L. Huertas Inspector (sign) *Jorge Huertas*

Report to: Div. Of Fire Prevention
Fire Department