

040011

WINDING



CERTIFICATE OF INSPECTION - NEW SEWER HOUSE CONNECTION

☐ Sanitary ☐ Storm ☒ Combination

Borough of BX

This below described sewer house connection has been laid from the property line to the existing sewer at premises:

N.B.#/P.R.A. 220553620 Block 5119 Lot 92
Under Permit Number 826877 Issued 11/6/20
Premises 4826 Barnes Ave
House Number and Street
Owner Ezzen Drier
Plumber Thomas Vitello M
Size and type of pipe laid 6"XHC I
Connected to 15" Combined Sewer laid in Barnes Ave
Size, Type
Street Avenue

I hereby certify that I made the inspection of the Sewer House Connection described above and that all work done under this permit has been properly completed in accordance with existing ordinances, rule and regulations.

Name R. Johnson Inspector
Signed [Signature] Date: 3/22/18
Signed [Signature] te: 4/20/18
Chief

PENALTY FOR FALSIFICATION:

Knowing falsification of any statement is a misdemeanor under section 26-124 of the Administrative Code and is punishable by a fine or imprisonment, or both.

Copies to: ☐ Borough Superintendent, Department of Buildings
☐ Borough Office, Bureau of Water Register
☐ Sewer Regulation and Control Section

File original in Borough Office, Sewer Regulation and Control

W/R

no rule.

House Number	4826	Street Name	Barnes Ave	Block	5119	Lot	92
--------------	------	-------------	------------	-------	------	-----	----

1. Was connection extended from curb connection? ☐ Yes, ☒ No

2. Was the connection placed on earth, stone or crushed rock, concrete cradle, concrete encasement or reinforced concrete encasement? (circle one)


3. Was connection made to existing spur or riser, fold in spur, MH connection or cut in? (circle one)

4. If connection was "cut in", was saddle or dutchman used? (if so, circle)

5. Length, size and material of new connection 18" of 6" XHC (Dep) 25' of 6" XHC (Dep)

6. Depth of connection at curbline is 84 (DOB) 8'7" (Dep) feet

7. All work was exposed and inspected.



NYC DEPT. OF BUILDINGS
HOUSE CONNECTION UNIT
RECEIVED
2018 APR 19 A 8:23