



TR4: Technical Report
Soil Investigation
Must be typewritten.

☒ Orient and affix BIS job number label here ☒

1 Location Information *Required for all applications.*

House No(s) 11 Street Name WEST 184 STREET
Borough BRONX Block 3199 Lot 128 BIN 2014341 CB No. 207
Work on Floor(s) Apt/Condo No(s)

2 Applicant Information *Required for all applications.*


Last Name PARBHUNATH First Name INDARDEO Middle Initial
Business Name IP CONCRETE TESTING & INSPECTION INC Business Telephone 718-641-5800
Business Address 101-01 101 AVENUE Business Fax
City QUEENS State NY Zip 11416 Mobile Telephone
E-Mail aainspectionsbuildings@gmail.com License Number 083868
☒ P.E. ☐ R.A.

3 Required Borings / Test Pits *Required for all applications.*

Number of Test Pits as Required as per NYC Construction Codes: TP-1

4 Plot Diagram *Required for all applications.*

Draw in ink to indicate scale. Show building outline or extension and location of all borings and/or test pits by dimensions. Borings and/or test pits shall be distributed according to the NYC Construction Codes.





TR4: Technical Report
Soil Investigation
Must be typewritten.

☒ Orient and affix BIS
job number label here ☒

1 Location Information Required for all applications.

House No(s) 11 Street Name WEST 184

Borough BRONX

Block 3199

Lot 128

BIN 2014341

CB No. 207

Work on Floor(s)

Apt/Condo No(s)

2 Applicant Information Required for all applications.

Last Name PARBHUNATH

First Name INDARDEO

Middle Initial

Business Name IP CONCRETE TESTING & INSPECTION INC

Business Telephone 347-960-9153

Business Address 101-01 101 AVENUE

Business Fax

City QUEENS

State NY

Zip 11417

Mobile Telephone

E-Mail aa inspectionsbuildings@gmail.com

License Number 083868


☒ P.E. ☐ R.A.

3 Required Borings / Test Pits Required for all applications.

Number of Test Pits as Required as per NYC Construction Codes: B-1

4 Plot Diagram Required for all applications.

Draw in ink to indicate scale. Show building outline or extension and location of all borings and/or test pits by dimensions. Borings and/or test pits shall be distributed according to the NYC Construction Codes.



5 Test Report Required for all applications.					
Date	Boring/ Test Pit #	Feet Below Curb	Soil Description	Class Number	Remarks
3/20/20	B-1	0-2	organic material ,sandy clay with broken bricks	6	Uncontrolled fill
		2-4	sandy clay with pebbles (sc	3b	Natural fill
		4-6	silty sand with pebbles (sm	3b	Natural fill
		6-8	fine sand with gravel(sm	3b	Natural fill
		8-10	fine sand with gravel(sm	3b	Natural fill
		10-12	fine sand with gravel(sm	3b	Natural fill
		12-14	fine sand with gravel(sm	3b	Natural fill
		14-16	brown fine sand (sm	3b	Natural fill
		16-18	coarse sand with soft rocks (sm	1d	Natural fill
		18-20	coarse sand with soft rocks (sm	1d	Natural fill
		20-22	coarse sand with soft rocks (sm	1d	Natural fill
		22-24	coarse sand with soft rocks (sm	1d	Natural fill
		24-25	coarse sand with soft rocks (sm	1d	Natural fill
		25.5ft	Hit rock 25.5ft spoon refusal		

6 Statements and Signatures Required for all applications.	
--	--

I hereby state that the above information is correct and complete to the best of my knowledge and that the above tests were performed in accordance with all Administrative Code Provisions and Departmental Rules, Regulations and Directives.

Falsification of any statement is a misdemeanor and is punishable by a fine or imprisonment, or both.

It is unlawful to give to a city employee, or for a city employee to accept, any benefit, monetary or otherwise, either as a gratuity for properly performing the job or in exchange for special consideration. Violation is punishable by imprisonment or fine or both.

Name (please print)

INDARDEO PARBHUNATH

03-20-2020

Signature

Date



P.E. / R.A. Seal (apply seal, then sign and date over seal)

Approvals - Internal Use Only			
Examined and Recommended for Approval		Approved	
Examiner Name		Borough Commissioner Signature	Date
Signature	Date		