



A Con Edison, Inc. Company



Consolidated Edison Company
Of New York, Inc.
4 Irving Place 10th Floor South
New York, NY 10003
www.conEd.com

6/1/2015

Perez, Amanda
1824 PATTERSON AVENUE
BRONX, NY 10473
Case ID: MC-111538

Re: Distributed Generation Equipment Interconnection Approval

Dear Mr. / Ms. Customer,

Congratulations! We would like to inform you that the application for interconnection you have submitted has been approved. Con Edison has confirmed that your equipment may operate in parallel.

As stated in the "New York State Standardized Interconnection Contract (for systems up to 2MW)," it is the customer's obligation to obtain all environmental and other permits required by governmental authorities for the construction and operation of the unit. Con Edison's authorization is only limited to the determination of the installation described in your application. It is the customer's responsibility to ensure that their DG equipment is in compliance with any other jurisdictions such as local building codes and ordinances.

If there are any modifications made to your equipment after the date of approval, you must contact your Con Edison Customer Project Manager immediately and resubmit an application. All customers are reminded of the continuing obligation to perform verification testing at least once every four years as well as any verification tests prescribed by the manufacturer. These tests and results are to be maintained in a log for inspection by Con Edison.

Sincerely,

Kevin Dekeris
Planning & Project Management
4 Irving Place
10th Floor North East
New York, NY 10003
O: (212) 460-2639
C: (917) 642-1787

Attach
Cc: file