



5/1/2018

Vincent Sapienza, P.E.
Commissioner

Anastasios Georgelis, P.E.
Acting Deputy
Commissioner
Bureau of Water &
Sewer Operations

59-17 Junction Boulevard
Flushing, NY 11373

Automated Design Consultants
15 Hardscrabble Hill Road
Chappaqua, New York 10514
Attn: Gregory Mortman, P.E.

To Whom It May Concern:

The hydrant flow test you requested in the vicinity of **2625 Grand Avenue, Bronx** was performed on **4/27/2018** at **10:15 AM** with the following results:

The static pressure taken on an 8 inch water main which is fed from two directions on the west side of Grand Avenue 1st hydrant north of West 192nd Street was **68** pounds per square inch. The residual pressure at this point was **67** pounds per square inch when 500 gallons of water per minute were flowing from the west side of Grand Avenue 1st hydrant south of West Kingsbridge Road.

This Department cannot guarantee that this pressure will be maintained in the future because a change may be needed in conformity with good engineering practices.

If you have any questions regarding engineering, and application status, please call (718) 595-7135.

Very truly yours,

A handwritten signature in black ink, appearing to read "Urszula Krajewski".

Urszula Krajewski, P.E.
Water Distribution Engineer
City Wide Hydraulic Testing Unit

File: FT2018-0803-201348

All hydrant flow test requests are to be addressed to: NYCDEP-BWSO; 59-17 Junction Blvd, 12th Fl., Flushing; NY 11373-5108, Attn: Citywide Hydraulic Flow Test Unit

Enclose payment for \$500 payable to NYC Water Board for each test. Indicate the test street, cross streets and borough for each test. All requests are to be made by US or overnight mail, no hand deliveries accepted.