



[CLICK HERE TO SIGN UP FOR BUILDINGS NEWS](#)

NYC Department of Buildings
OATH/ECB Violation Details

[Click here for more information about Severity, Violation and Hearing Statuses](#)

Premises: 1 EAST FORDHAM ROAD BRONX

Filed At: 9 EAST FORDHAM ROAD , BRONX , NY 10468

BIN: 2094673 Block: 3189 Lot: 1

Community Board: 207

OATH/ECB Violation Summary

VIOLATION OPEN

OATH/ECB Violation Number: 34129829K

Severity: NON-HAZARDOUS

Certification Status: NO COMPLIANCE RECORDED

Penalty Balance Due: \$0.00

Hearing Status: WRITTEN OFF

Respondent Information

Name: SAVE-A-STORES

Violation Details

Violation Date: 01/24/1996

Violation Type: CONSTRUCTION

Served Date: 03/13/1996

Inspection Unit:

Infraction Codes

Section of Law

Standard Description

B04

27-147

WORK WITHOUT A PERMIT

Specific Violation Condition(s) and Remedy:

WORK WITHOUT A PERMIT WORK NOTED 1-REMOVING INTERIOR PARTITION ANS INSTALLING HUNG CEILING 2 CREATING A FLOOR OPENING APPROX 8 WIDE BY 12 LONG AND CONCERTET & METAL STAIRS PLACED AT FRONT LOADING DOWN TO CELLAR

Issuing Inspector ID: 0669

DOB Violation Number: 012496C7AA2VW

Issued as Aggravated Level: NO

Dept. of Buildings Compliance History and Events

Certification Status: NO COMPLIANCE RECORDED

Compliance On:

A Certificate of Correction must be submitted to the Administrative Enforcement Unit (AEU) for all violations. A violation that is not dismissed by OATH/ECB will continue to remain ACTIVE or "open" on DOB records until acceptable proof is submitted to the AEU, even if you have paid the penalty imposed by OATH/ECB.

OATH/ECB Hearing Information

Hearing Status: WRITTEN OFF

OATH/ECB Penalty Information

Penalty Imposed: \$1,000.00

Adjustments: \$-1,000.00

Amount Paid: \$0.00

Penalty Balance Due: \$0.00

Court Docket Date: 10/31/1996

If you have any questions please review these [Frequently Asked Questions](#), the [Glossary](#), or call the 311 Citizen Service Center by dialing 311 or (212) NEW YORK outside of New York City.