



AI1: Additional Information Must be typewritten.

☒ Orient and affix BIS job number label here ☒

Page number 01 of 01 BIS Document No. 01

1 Location and Job Information Required for all applications.

House No(s) 2596 Street Name BRIGGS AVENUE

Borough BRONX Block 3293 Lot 173 BIN 2016831 CB No. 207

2 Revisions to Plans/Drawings Required whenever updating plans. All revisions for each page must be clearly described in section 3.

Submission is part of a Post Approval Amendment (PAA)? ☐ Yes PW1 required ☒ No Indicate all actions for this submission:

Action	Original/New/ Omit Page ID	Superseding Page ID	Action	Original/New/ Omit Page ID	Superseding Page ID	Action	Original/New/ Omit Page ID	Superseding Page ID	Action	Original/New/ Omit Page ID	Superseding Page ID
S	A-100	A-100									
S	A-300	A-300									
S	A-400	A-400									

For "Action" use "N" for new page, "S" for superseding page, "O" for omitting page. Is this section continued on additional AI1 forms? ☐ Yes ☒ No

3 Additional Information Required for all applications.

OBJECTION: BC1013.5 MECHANICAL EQUIPMENT. GUARDS SHALL BE PROVIDED WHERE APPLIANCES, EQUIPMENT, FANS, ROOF HATCH OPENINGS OR OTHER COMPONENTS THAT REQUIRE SERVICE ARE LOCATED WITHIN 10 FEET (3048 MM) OF A ROOF EDGE OR OPEN SIDE OF A WALKING SURFACE AND SUCH EDGE OR OPEN SIDE IS LOCATED MORE THAN 30 INCHES (762 MM) ABOVE THE FLOOR, ROOF OR GRADE BELOW.

PAGE: 3

RESOLUTION: A PROTECTIVE RAILING THAT IS 42 INCHES ABOVE THE ROOF SURFACE IN HEIGHT IS NOT NEEDED IN THAT LOCATION BECAUSE THERES AN ADJ ACENT BUILDING ATTACHED TO THE ROOFTOP MUCH HIGHER THAN 42 INCHES AS SHOWN IN PAGE 1 OF PLANS.

OBJECTION: FC 504.4.5 ROOFTOP CLEAR PATH PROTECTION. ADEQUATE PROTECTION, IN THE FORM OF A SECURELY AFFIXED PROTECTIVE RAILING OR BARRIER THAT IS 42 INCHES (1067 MM) ABOVE THE ROOF SURFACE IN HEIGHT ALONG THE CLEAR PATH, SHALL BE PROVIDED FOR ANY SHAFT, BUILDING PERIMETER OR ELEVATION ADJOINING THE CLEAR PATH OR ROOFTOP PERIMETER ACCESS LANDING (EXCEPT THE ROOFTOP ACCESS LANDING ITSELF).

PAGE: 1, 3 & 4

RESOLUTION: PROVIDED 3'-6" PROTECTIVE BARRIER ON FRONT EDGE OF ROOF.

I have self-certified compliance of objections. I am aware that the Commissioner will rely upon the truth and accuracy of the above statement as to compliance with the provisions of all applicable building laws and regulations. If non-compliance with such laws is disclosed at any later examination or review, I will take the necessary remedial measure to obtain objection compliance expeditiously. I further realize that any falsification of facts will render me liable for any legal and disciplinary action by the Department of Buildings and other appropriate authorities.

I have read the above statement and have authorized the request for 'self-certification' of objection(s) by the applicant for work specified on the plans and the application. I agree to comply with any requirements for remedial measures, if same becomes necessary.



Falsification of any statement is a misdemeanor and is punishable by a fine or imprisonment, or both. It is unlawful to give to a city employee, or for a city employee to accept, any benefit, monetary or otherwise, either as a gratuity for properly performing the job or in exchange for special consideration. Violation is punishable by imprisonment or fine or both. I understand that if I am found after hearing to have knowingly or negligently made a false statement or to have knowingly or negligently falsified or allowed to be falsified any certificate, form, signed statement, application, report or certification of the correction of a violation required under the provisions of this code or of a rule of any agency, I may be barred from filing further applications or documents with the Department.

Name (please print) MICHELLE ROSE CONTRERAS
Signature _____ Date _____

P.E. / R.A. Seal (affix seal and sign over seal)