

ORDER TYPE POMTR PO-METER PERMIT

ACCOUNT 8001032071001 NAME 1520 WEST 10 STREET LLC PHON

ADD NM BORO 3 BLK 6596 LOT 15 SEC 20 COMM BRD :

ADDR 1520 W 10 ST SPCL PREM INS

BROOKLYN NY 11204

SPCL READ INSTR

BUILDING CLASS D1 SEMI W/O STORES

CROSS STREETS AVENUE O AVENUE P

UMS VARIANCE CODE

NON UMS VARIANCE CODE



DEP BCS

2009 JUL 22 P 12:51

BCS  
ACCEPTED PERMIT

ASGN TO 0000 STATUS A PEND/INITIATED REAS A NORMAL ISS DATE 04/30/09

CONTRACT 0000 BATCH 00000 PLACED BY PASSALACQUA/ STACY PH #

WANTED BY DATE 01/29/10 TIME 0000 CREATED BY AL DATE 04/29/09

CONTRACT ITEM CODES

SPCL INST PO-METER PERMIT INSTALL 4" DDCV WITH 3/4" BYPASS METER TO COVER

E.P. ON 4" COMB. SPRINKLER SERVICE - BBL 3/6596/15 NEW BLDG

POMTR - PO-METER PERMIT

PERMIT NUMBER 540316

SVC SIZE 008 SVC SIZE DESC 4" TAP SIZE 014 TAP SIZE DESC 8" X 4"

FEE 35.00 NO DAYS USAGE 000 START/END DATE 00/00/00 00/00/00

APPLICATION DATE 00/00/00 EXPIRE DATE 00/00/00 START/END TIME 0000 0000

PLUMBER LICENSE NO 0001943 EXPIRE DATE 06/12/09 STATUS A ACTIVE-GOOD

NAME MICHAEL J PASSALACQUA

ADDRESS 777 EAST 96 STREET BROOKLYN, NY 11236

This permit is  
valid for thirty  
(30) days.

ADDITIONAL ORDER INFORMATION

METER PERMIT

NOTE: ALL METERS MUST BE REMOTE READY.

PERMIT ORDER STATUS

( ) G - PERMIT COMPLETED

( ) P - PERMIT CANCELED

NEW METER ATTRIBUTE AND NEW METER INSTALLATION INFORMATION FOR

METER NUMBER:

( ) NEW METER MANUFACTURER

( ) NEW METER SIZE

( ) NEW METER TYPE

( ) NEW METER LOCATION CODE

( ) NEW METER SERIAL NUMBER

( ) NEW METER READING 1

( ) NEW METER READING 2 (FOR COMPOUND METER)

( ) NEW REMOTE ID 1

( ) NEW REMOTE ID 2 (FOR COMPOUND METER)

( ) NEW REMOTE LOCATION CODE

(52266258)

PERMIT ISSUED BY  
THE CITY OF NEW YORK  
BROOKLYN DEP BCS

Wahl 709 PCA.

NOTE: REMOTE RECEPTACLES  
ARE REQUIRED FOR ALL  
NEW METER INSTALLATIONS.

1520 West 10 St.



|        | FULL | INTER | LOW  |
|--------|------|-------|------|
| Fast % | 99.1 | 100.0 | 99.8 |

Bench 11  
3/4 x 3/4  
DM2C21  
Pos H 14  
Gear

Reg. SB

05/26/09

14:23 PM



09911008099A

36 N

METER TESTED BY (INSPECTOR ID): -

I HERBY CERTIFY THAT ALL CONNECTIONS ARE PROPER AND THAT THE PREMISES ARE METERED IN ACCORDANCE WITH THIS PERMIT.

DATE SET: 7/14/09

PLUMBER NAME:

PLUMBER ADDRESS:

**TRIBORO PLUMBING & HEATING CORP.**

777 East 96th Street  
BROOKLYN, NEW YORK 11236

IF CALIBRATION WAS REQUIRED, WAS THE METER CALIBRATED IN PLACE?

☐ YES

( ) NO

COMPLETION DATE \_\_\_\_\_ WO STATUS \_\_\_\_\_  
COMPLETED BY (ID) \_\_\_\_\_ WO STATUS REASON \_\_\_\_\_  
COMPLETION TIME IN \_\_\_\_\_ COMPLETION TIME OUT \_\_\_\_\_

COMMENTS \_\_\_\_\_