



THE CITY OF NEW YORK

DEPARTMENT OF BUILDINGS CERTIFICATE OF BOILER INSPECTION

SEC. 28-303 ADMINISTRATIVE CODE:

PERIODIC INSPECTION:-ALL BOILERS AS DEFINED IN SECTION 204 OF THE NEW YORK
STATE LABOR LAW SHALL BE INSPECTED AT LEAST ONCE A YEAR BY A QUALIFIED
DEPARTMENT OF BUILDINGS BOILER INSPECTOR OR AN APPROVED AGENCY

Address 290 WASHINGTON Ave Borough Brooklyn

Boiler No. 81529- Serial No. 01-02

Style of Boiler H.A.M.P. 28A8 Type CAST IRON

Rating low pressure BTU Input 2,436,000 Date Built _____

THIS IS TO CERTIFY THAT THE ABOVE DESCRIBED BOILER HAS BEEN
INSPECTED ON THE FOLLOWING DATES. 310247952

DATE OF INSPECTION	HYDROSTATIC PRESSURE APPLIED	APPROVED MAXIMUM WORKING PRESSURE	INSPECTOR
	Pounds Per Square Inch		
4-9-09	FIRST TEST	15 P.S.I.	W 2300

SEC. 204 LABOR LAW—SUB SECTION 4.1.8

EXCESSIVE PRESSURE OR TEMPERATURE: NO PERSON SHALL SUFFER OR PERMIT A BOILER TO
BE OPERATED AT A PRESSURE EXCEEDING THE MAXIMUM ALLOWABLE WORKING PRESSURE OR
AT A TEMPERATURE EXCEEDING THE MAXIMUM ALLOWABLE WORKING TEMPERATURE STATED ON
THE LATEST CERTIFICATE OF INSPECTION.

THIS CERTIFICATE MUST BE POSTED IN THE BOILER ROOM

[Signature]
COMMISSIONER

Commissioner

Form 276 (Rev. 03/08)

