



**DEPARTMENT OF
ENVIRONMENTAL
PROTECTION**

59-17 Junction Boulevard
Flushing, New York 11373

**Steven W. Lawitts
Acting Commissioner**

**James J. Roberts, P.E.
Deputy Commissioner**

**Bureau of Water and
Sewer Operations**

Tel (718) 595-5330
Fax (718) 595-5342
jroberts@dep.nyc.gov



July 1st, 2009

H2 Consulting P.E., P.C.
87 Walker Street, 3rd Floor
New York, NY 10013
Attn: Harry H. Hong, P.E.

To Whom It May Concern:

The hydrant flow test you requested in the vicinity of **69 Bay 20th Street, Brooklyn** was performed on **6/15/2009** at **11:20 AM** with the following results:

The static pressure taken on the west side of Bay 20th Street 2nd hydrant south of 86th Street was 49 pounds per square inch. The residual pressure at this point was 47 pounds per square inch when 500 gallons of water per minute were flowing from the west side of Bay 20th Street 1st hydrant north of Benson Avenue.

This Department cannot guarantee that this pressure will be maintained in the future because a change may be needed in conformity with good engineering practices.

The flow test was performed on an 8 inch water main, which is fed from two directions.

If you have any questions on the above, please contact me at (718) 595-7029, fax at (718) 595-7408.

Very truly yours,

Edward Ayvazyan P.E.

Edward Ayvazyan, P.E.
Water Distribution Engineer
City Wide Hydraulic Testing Unit

File: FT2009-0558-L17-0158

All hydrant flow test requests are to be addressed to: NYCDEP-BWSO; 59-17 Junction Blvd, 12th Fl., Flushing; NY 11373-5108, Attn: Citywide Hydraulic Flow Test Unit

Enclose payment for \$250 payable to NYC Water Board for each test. Indicate the test street, cross streets and borough for each test. All requests are to be made by US or overnight mail, no hand deliveries accepted.



www.nyc.gov/dep

DIAL 311 Government Information
and Services for NYC