



Buildings

OP-98 Notice/Results—Self-Certification of Plumbing, Sprinkler, Standpipe Inspection(s) & Test(s)

A copy of this completed notice must be retained for re-submission with results.



1 Permit No. 320307994 **Document No.** 01 **Permit Type** (check one only): ☒ PL ☐ SP ☐ SD ☐ LAA

Borough Brooklyn **Block** 3335 **Lot** 1 **House No** 557 **Street Name** Knickerbocker Avenue

2 Permit Applicant E-Mail: tony@1energygroup.com **Business Phone** (718) 633-3631 **Fax No.** (631) 691-1711

Last Name MONGONE **First Name** ANTHONY **M.I.** **Business Name** TRADELINE PLUMBING INC.

Address 978 39TH STREET **City** BROOKLYN **State** NY **ZIP** 11219 **License No.** 1560 ☒ LMP ☐ LFSC

3 Inspection Data Inspection/test scheduled for: 9/6/12 (mm/dd/yy) **Time:** ☐ 8:00am ☐ 8:30 ☐ 9:00 ☐ 9:30 ☐ 10:00 ☐ 10:30 ☐ 11:00 ☒ 11:30 ☐ 12:30pm

Apts and Floors: Cellar ☐ 100pm ☐ 1:30 ☐ 2:00 ☐ 2:30 ☐ 3:00 Meeting Location:

4 Notice/Result (Select one: PL, SP, SD only)

Systems: Plumbing (PL)										Systems: Sprinkler (SP)										Systems: Standpipe (SD)															
Inspections			Underground			Roughing			Finish			Inspections			Underground			Roughing			Finish			Inspections			Underground			Roughing			Finish		
Notice	Results		Notice	Results		Notice	Results		Notice	Results		Notice	Results		Notice	Results		Notice	Results		Notice	Results		Notice	Results		Notice	Results							
Sprinkler - PL																																			
Water/Sanitary - PL																																			
Storm - PL																																			
Gas - PL																																			
Medical Gas - PL																																			
Tests			Notice			Results			Tests			Notice			Results			Tests			Notice			Results			Tests			Notice			Results		
Hydrostatic - PL																																			
Water - Sanitary																																			
Pressure - Water																																			
Water Storm																																			
Gas																																			
Medical Gas																																			

Additional Information/Comments:

☐ Submitted with minor variations, described here:

☐ Legalization ☐ Gas to Gas Appliance Direct Replacement ☐ Remove/Cap ☐ Detention ☐ Drywell/Retention

5 Gas Meters/Risers Data (Check all applicable to this inspection. Include gas usages for each listed meter(s)/riser(s)) ☒ Gas requested for listed meters and risers

No. of Meters: 1 **Location(s) (Floor/Apt.):** existing in basement **No. of Risers:** 1 **Location(s) (Floor/Apt.):** basement to roof ☐ Welded Gas Piping

Gas usage: ☒ Heat ☐ Boiler Pilot for oil burner ☐ Water Heater ☐ Dryer

☐ Cooking ☒ Tankless Coil ☐ HVAC ☐ Fire Place ☐ Other (describe):

6 Certifying Applicant E-Mail: tony@1energygroup.com **Business Phone** (718) 633-3631 **Fax No.** (631) 691-1711

Last Name MONGONE **First Name** ANTHONY **M.I.** **Business Name** TRADELINE PLUMBING

Address 978 39TH STREET **City** BROOKLYN **State** NY **ZIP** 11219 **License No.** 1560 ☒ LMP ☐ LFSC ☐ P.E. ☐ R.A.

7 Applicant Statements and Signatures ☐ All Comments resolved, review for sign-off ☐ All required back-up documents attached

I certify the statements herein are correct and comply with the NYC Building code. I meet the requirements of the NYC Building code as they relate to the experience requirements set forth for gas tests. I realize falsification of any statements is a misdemeanor under §28-211.1 of the Administrative code punishable by a fine or imprisonment or both and may result in removal from participation in the self-certification program and/or disciplinary action by the Licensed Master Plumber or Licensed Fire Suppression Piping Contractor License Board.

Print Name of Certifying Applicant ANTHONY MONGONE	SEAL	Print Name of Permit Applicant or Alternative licensee from same firm (LMP/LFSC) ANTHONY MONGONE	SEAL
Signature		Signature	
Date	11/15/12	Date	11/15/12

FOR DOB USE ONLY

Reviewed by: **Date:** 11/16/12 **Entered by:** **R.S.O. by:** **S/O by:**

Need gas test & gas cap for roof, need gas finish

GAS AUTHORIZATION DENIED

RECEIVED