



AI1: Additional Information
Must be typewritten.



Page number _____ of _____ BIS Document No. _____

1 Location and Job Information Required for all applications.

House No(s) 25

Street Name Plaza Street West

Borough Brooklyn

Block 1062

Lot 11

BIN 3024549

CB No. 306

2 Revisions to Plans/Drawings Required whenever updating plans. All revisions for each page must be clearly described in section 3.

Submission is part of a Post Approval Amendment (PAA)? ☐ Yes PW1 required ☐ No Indicate all actions for this submission:

Action	Original/New/ Omit Page ID	Superseding Page ID	Action	Original/New/ Omit Page ID	Superseding Page ID	Action	Original/New/ Omit Page ID	Superseding Page ID	Action	Original/New/ Omit Page ID	Superseding Page ID

For "Action" use "N" for new page, "S" for superseding page, "O" for omitting page.

Is this section continued on additional AI1 forms? ☐ Yes ☐ No

3 Additional Information Required for all applications.

The partial demolition and re-construction of parapet walls (BC 2109.5.5) is not subject to Special Inspections for Structural Safety - Structural Stability under BC 1704.19 because the work does not require "design" as defined in BC Chapter 33 and there will be no temporary diminution of stability or integrity of a structural system.

The removal and replacement of steel lintels is not subject to Special Inspections for Structural Steel - Welding under BC 1704.3.1, Structural Steel - Erection and Bolting under BC 1704.3.2 and 1704.3.3, or Structural Cold-formed Steel under BC 1704.3.4 because the lintels are loose-laid and are not cold-formed steel as defined in BC 2202.1.

The removal and replacement of steel lintels is not subject to Special Inspections for Structural Safety - Structural Stability under BC 1704.19 because the work does not require "design" as defined in BC Chapter 33 and there will be no temporary diminution of stability or integrity of a structural system.

The removal and replacement of masonry is not subject to a Special Inspection for Masonry under BC 1704.5 because it falls within the exception under BC 17504.5(1); the masonry is of empirical design (BC 2109.1), is a veneer (BC 1402.1), and is part of a non-essential building (Table 1604.5).

The removal and replacement of the outer wythe masonry is not subject to a Special Inspection for Structural Safety - Structural Stability under BC 1704.19 because the work does not require "design" as defined in BC Chapter 33 and there will be no temporary diminution of stability or integrity of a structural system.

Falsification of any statement is a misdemeanor and is punishable by a fine or imprisonment, or both. It is unlawful to give to a city employee, or for a city employee to accept, any benefit, monetary or otherwise, either as a gratuity for properly performing the job or in exchange for special consideration. Violation is punishable by imprisonment or fine or both. I understand that if I am found after hearing to have knowingly or negligently made a false statement or to have knowingly or negligently falsified or allowed to be falsified any certificate, form, signed statement, application, report or certification of the correction of a violation required under the provisions of this code or of a rule of any agency, I may be barred from filing further applications or documents with the Department.

Name (please print) Charles A. Merritt
Signature Charles A. Merritt Date 12/24/11
P.E. / R.A. Seal (apply seal, then sign and date over seal)

