



**Environmental
Protection**

Carter H. Strickland, Jr.
Commissioner

James J. Roberts, P.E.
Deputy Commissioner
Bureau of Water &
Sewer Operations
jroberts@dep.nyc.gov

59-17 Junction Boulevard
Flushing, NY 11373

DEPT OF BLDGS320442008 Job Number

ES614035493 Scan Code

April 30th, 2012

Safety Fire Sprinkler Corp.
1070 38th Street
Brooklyn, New York 11219
Attn: Chaim Asher Reisman

To Whom It May Concern:

The hydrant flow test you requested in the vicinity of **207 Amboy Street, Brooklyn** was performed on **4/17/2012** at **11:00 AM** with the following results:

The static pressure taken on the east side of Amboy Street 1st hydrant north of Blake Avenue was 58 pounds per square inch. The residual pressure at this point was 56 pounds per square inch when 500 gallons of water per minute were flowing from the east side of Amboy Street 1st hydrant south of Sutter Avenue.

This Department cannot guarantee that this pressure will be maintained in the future because a change may be needed in conformity with good engineering practices.

The flow test was performed on an 8 inch water main, which is fed from two directions.

If you have any questions on the above, please contact me at (718) 595-7135, fax at (718) 595-7408.

Very truly yours,

Urszula Krajewski, P.E.
Water Distribution Engineer
City Wide Hydraulic Testing Unit

File: FT2012-0611-N23-0474

All hydrant flow test requests are to be addressed to: NYCDEP-BWSO; 59-17 Junction Blvd, 12th Fl., Flushing; NY 11373-5108, Attn: Citywide Hydraulic Flow Test Unit

Enclose payment for \$500 payable to NYC Water Board for each test. Indicate the test street, cross streets and borough for each test. All requests are to be made by US or overnight mail, no hand deliveries accepted.