



Plumbing Division
Sprinkler Inspection Report



Premises 207 Amboy Street Borough Brooklyn Date 10/29/2012
Approved Plan # 320442008 Stories 1 Feet 25' When Installed 10/12
Construction Combustible Occupancy Residential Area 5000 Sqf
No. of water supplies 1 Wet or Dry Wet

Supply: City Water Connection Size 2" Fed 2 ways no
Curb or P.I. Valve curb Name & size of meter metro 2"
Valves sealed open YES Lbs. Pressure 50

Gravity Tank Capacity NA Heated Height over top sprinkler line
Size fill line Size Overflow Emergency Drain Valve
Type and Size Tank piping brass Exposed piping weatherproofed
Ladder secured Location tank check and control valve
Valves sealed open No. Fill Pumps Size Type
Capacity in gallons How operated

Pressure Tank Capacity NA Tank House Heated Size Fill Line
Emergency Drain Valve Type and Size Air Pressure
Water Level Location tank check and control valves
Control valves sealed open

Risers No. NA Size dead risers Size live risers
Size drain risers Floor control valves Sealed open
Main Drain Size Location inspectors Test valve
Exposed Piping or Heads Location How protected
No. Cold Weather Valves Location App'd signs

No. Dry Valves NA Name Type Water Pressure
Air Pressure Dry Valve room heated
No. of heads controlled by each dry pipe valve

No. Alarm Valves NA Size and type Local Supervisory
High-Low Gravity High-Low Pressure Flow Alarm

Fire Pumps: Name NA Type Capacity in Gallons
Or
Booster Pumps: Checked Draws from Size of suction line
Size of discharge line How operated Supervisory
Adequate pressure in system

No. Siamese connections 1 Size 3" App'd Type YES
Location Amboy St. Signs yes Type of drips ABD
Caps painted green yes
Is every square foot of the building sprinklered yes
If not, portion sprinklered
Extra heads & wrench provided yes Painted or corroded heads no

Is installation as per app'd plan yes As per Fire Dept. order
Entire system tested at 200 p.s.i. yes Result satisfactory
Certificate of Fitness required YES

Recommendations:

OWNER'S NAME AND ADDRESS	CONTRACTOR'S NAME AND ADDRESS
AMBOY DEVELOPMENT EAST 325 EAST 104TH STREET NEW YORK NY 10029	

Inspector (sign) Inspector (print) Avi Shteierman

Test Listed
By

Report to: Div. Of Fire Prevention,
Fire Department