

ORDER TYPE POMTR PO-METER PERMIT

ACCOUNT 0001045044001

ADD NM

ADDR 198 SKILLMAN ST
BROOKLYN NY 11238

SPCL READ INSTR

BUILDING CLASS

CROSS STREETS

UMS VARIANCE CODE

NON UMS VARIANCE CODE

NAME MEIR SCHWEID

BORO 3 BLK 1927 LOT 41

PAGE 1 OF 2
PHONE 718-963-1971
SEC 7 COMM BRD 303

SPCL PREM INS

V0 VAC ZONE 1-3 FAM

WILLOUGHBY AVENUE

DE KALB AVENUE

PERMIT ISSUED BY
THE CITY OF NEW YORK
BROOKLYN DEP/BCS

ASGN TO 0000 STATUS A PEND/INITIATED REAS A NORMAL

CONTRACT 0000 BATCH 00000 PLACED BY HUNG(JACKIE)

WANTED BY DATE 09/17/14 TIME 0000

CREATED BY RS

ISS DATE 09/17/13

PH #

DATE 09/17/13

CONTRACT ITEM CODES

SPCL INST PO-METER PERMIT INSTALL 3" DDCV WITH 3/4" BYPASS METER TO COVER
SPRINKLER SERVICE. 3" COMBINED. NEW BLDG.

POMTR - PO-METER PERMIT

PERMIT NUMBER 667589

SVC SIZE 000 SVC SIZE DESC

TAP SIZE 000 TAP SIZE DESC

FEE 35.00 NO DAYS USAGE 000 START/END DATE 00/00/00 00/00/00

APPLICATION DATE 00/00/00 EXPIRE DATE 00/00/00 START/END TIME 0000 0000

PLUMBER LICENSE NO 0001892 EXPIRE DATE 08/26/14 STATUS A ACTIVE-GOOD

NAME SIMON HUNG

ADDRESS 32-37 62 STREET WOODSIDE, NY 11377

ADDITIONAL ORDER INFORMATION

METER PERMIT

NOTE: ALL METERS MUST BE REMOTE READY.

PERMIT ORDER STATUS

() G -- PERMIT COMPLETED

() P -- PERMIT CANCELED

NEW METER ATTRIBUTE AND NEW METER INSTALLATION INFORMATION FOR

METER NUMBER:

(Neptune) NEW METER MANUFACTURER

(3/4") NEW METER SIZE

(bypass) NEW METER TYPE

() NEW METER LOCATION CODE

(62290907) NEW METER SERIAL NUMBER

() NEW METER READING 1

() NEW METER READING 2 (FOR COMPOUND METER)

() NEW REMOTE ID 1

() NEW REMOTE ID 2 (FOR COMPOUND METER)

() NEW REMOTE LOCATION CODE

() LOW FLOW - IN-READ/ OUT READ

() INTERFLOW - IN-READ/OUT READ

() HIGH FLOW - IN-READ/OUT READ

() CAPACITY (GALLONS, CUBIC FEET)

() NUMBER OF READ DIALS-1

() TOTAL NUMBER OF DIALS-1

() NUMBER OF READ DIALS-2 (FOR COMPOUND METER)

() TOTAL NUMBER OF DIALS-2 (FOR COMPOUND METER)

() CONSTANT

() MEASURES (CCF, GALLONS)

() CAPABILITIES (PB-PRIMARY BYPASS OR METER)

() SEAL NUMBER 1

() SEAL NUMBER 2 (FOR COMPOUND METER)

METER TEST DATE

| |--| |--| |


 DEP/BCS BROOKLYN BOROUGH OFFICE
 APPROVAL PENDING REVIEW & INSPECTION
 DATE 12/24/13
 CSR

COPY

ORDER TYPE POMTR PO-METER PERMIT
ACCOUNT 0001045044001 NAME MEIR SCHWEID

PAGE 2 OF 2
PHONE 718-963-1971

METER TESTED BY (INSPECTOR ID): -

I HERBY CERTIFY THAT ALL CONNECTIONS ARE PROPER AND THAT THE
PREMISES ARE METERED IN ACCORDANCE WITH THIS PERMIT.

DATE SET:

PLUMBER NAME:

PLUMBER ADDRESS:

12-23-13

Simon Hung
32-27 62nd St
Queens, NY 11377

IF CALIBRATION WAS REQUIRED, WAS THE METER CALIBRATED IN PLACE?

() YES

() NO

COMPLETION DATE
COMPLETED BY (ID)
COMPLETION TIME IN

NO STATUS
NO STATUS REASON
COMPLETION TIME OUT

COMMENTS

NEPTUNE



LOW

99.7

INT

100.5

HIGH

99.5

10/30/13

8:45 AM

Pallet # 11
Position # 11

