

**THE CITY OF NEW YORK  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF SEWERS**

**BOROUGH OF BROOKLYN**

**CERTIFICATE OF INSPECTION - NEW SEWER HOUSE CONNECTION**

The below described sewer house connection has been laid from the property line to the existing sewer at premises:

820597653

N.B. # 320597644 Block 556 Lot 114, 115  
P.R.A.

Under Permit Number 788769, 788770 Issued 2/27, 2016

Premises 117, 117A KING ST  
House Number and Street

located \_\_\_\_\_ side \_\_\_\_\_ feet \_\_\_\_\_ of \_\_\_\_\_

Sewer ALESSANDRO ZAMPARDI

Plumber REMO DISCHINO

Size and type of pipe laid 6" EVC PIPE

Connected to 15" COMBINED Sewer laid in  
size, type

KING ST  
Street, Avenue

I hereby Certify that I made the inspection of the Sewer House Connection described above and that all work done under this Permit has been properly completed in accordance with existing ordinances, rule and regulations.

Name S. SINDB  
Inspector, Division-Sewer Construction

Signed [Signature] Date: 01/06/17

Noted [Signature] Date: 1/9/17  
Engineer in Charge


**PENALTY FOR FALSIFICATION:**

Falsification of any statement made herein is an offense punishable by a fine of imprisonment of both (N.Y.C. Administrative Code, Section 1151-90)

Copies to: Borough Superintendent, Department of Buildings  
Borough Office, Bureau of Water Register  
Sewer Regulation and Control Section  
File original in Borough Office, Sewer Regulation & Control

|              |             |       |          |
|--------------|-------------|-------|----------|
| 117, 117A    | KING ST     | 556   | 114, 115 |
| house number | street name | block | lot      |

1. Was connection extended from curb connection? ☐ yes, ☒ no
2. Was the connection placed on earth, stone or crushed rock, concrete grade, concrete encasement or reinforced concrete encasement? (circle one)
3. Was connection made to existing spur or riser or cut in? (circle one)
4. If connection was "cut in", was saddle or cut in used? (if so, circle)
5. Length, size and material of new connection 30' of 6" black pipe
6. Depth of connection at curb line is 5 1/2 feet.
7. All work was exposed and inspected. 117A



date 04/06/17 signed [Signature]