



Environmental
Protection

Emily Lloyd
Commissioner

James J. Roberts, P.E.
Deputy Commissioner
Bureau of Water &
Sewer Operations

59-17 Junction Boulevard
Flushing, NY 11373

2/17/2016

Lam Engineer, P.C.
4891 187th Street
Fresh Meadows, New York 11365
Attn: Yuk Lam, P.E.

To Whom It May Concern:


The hydrant flow test you requested in the vicinity of **758 50th Street, Brooklyn** was performed on **2/16/2016** at **11:59 AM** with the following results:

The static pressure taken on a 12 inch water main which is fed from two directions on the north side of 50th Street 1st hydrant west of 8th Avenue was **60** pounds per square inch. The residual pressure at this point was **59** pounds per square inch when 500 gallons of water per minute were flowing from the north side of 50th Street 2nd hydrant east of 7th Avenue.

This Department cannot guarantee that this pressure will be maintained in the future because a change may be needed in conformity with good engineering practices.

If you have any questions regarding engineering, and application status, please call (718) 595-3958.

Very truly yours,


Jose A. Cortes, P.E.
Water Distribution Engineer
City Wide Hydraulic Testing Unit

File: FT2016-0025-303827

All hydrant flow test requests are to be addressed to: NYCDEP-BWSO; 59-17 Junction Blvd, 12th Fl., Flushing; NY 11373-5108, Attn: Citywide Hydraulic Flow Test Unit

Enclose payment for \$500 payable to NYC Water Board for each test. Indicate the test street, cross streets and borough for each test. All requests are to be made by US or overnight mail, no hand deliveries accepted.