

NYC
Environmental
Protection

Carter H. Strickland, Jr.
Commissioner

James J. Roberts, P.E.
Deputy Commissioner
Bureau of Water &
Sewer Operations
jroberts@dep.nyc.gov

59-17 Junction Boulevard
Flushing, NY 11373

January 3rd, 2012

Automated Design Consultants
15 Hardscrabble Hill Road
Chappaqua, New York 10514
Attn: Gregory Mortman, P.E.



To Whom It May Concern:

The hydrant flow test you requested in the vicinity of **203, 205 & 207 Palmetto Street, Brooklyn** was performed on **12/13/2011** at **2:50 PM** with the following results:

The static pressure taken on the west side of Palmetto Street 2nd hydrant north of Central Avenue was 51 pounds per square inch. The residual pressure at this point was 50 pounds per square inch when 500 gallons of water per minute were flowing from the west side of Palmetto Street 1st hydrant south of Wilson Avenue.

This Department cannot guarantee that this pressure will be maintained in the future because a change may be needed in conformity with good engineering practices.

The flow test was performed on an 8 inch water main, which is fed from two directions.

If you have any questions on the above, please contact me at (718) 595-7440, fax at (718) 595-7408.

Very truly yours,

Urszula Krajewski, P.E.
Water Distribution Engineer
City Wide Hydraulic Testing Unit

File: FT2011-1737-M25-0407

All hydrant flow test requests are to be addressed to: NYCDEP-BWSO; 59-17 Junction Blvd, 12th Fl., Flushing; NY 11373-5108, Attn: Citywide Hydraulic Flow Test Unit

Enclose payment for \$500 payable to NYC Water Board for each test. Indicate the test street, cross streets and borough for each test. All requests are to be made by US or overnight mail, no hand deliveries accepted.