



NYC DEPARTMENT OF ENVIRONMENTAL PROTECTION
Asbestos Control Program
59-17 Junction Boulevard, 8th Floor, Flushing, NY 11373
ASBESTOS ASSESSMENT REPORT



1. NYC DOB Job # (if applicable) _____ **Control Number: 3046939**

2. Premise No. 315 Street Name Sutter Avenue Borough Brooklyn Zip 11212

Bldg# 2 at Hughes

3. AKA Apartments Type of Facility Residence BIN 3333397 Block 03526 Lot 0021

New York City Housing

4. Building Owner Authority (NYCHA) Address 90 Church Street, 12th Floor

5. City Manhattan State NY Zip 10007 Contact Person Richard Morrison

6. Tel. # (212) 306-3154 Fax # (212) 306-5118 Email Richard.Morrison@nycha.nyc.gov

7. Description of the Entire Scope of Work

INSTALLATION OF PIPE SCAFFOLDING AT BUILDING FACADES AND ROOF BULKHEAD.

8. I, MIKHAIL POPOVETSKIY, have conducted an asbestos investigation on

Name of Certified Asbestos Investigator

10/17/2012 in accordance

Date(s)

with Sections 1-16 and 1-28 of the NYC DEP Asbestos Control Program Rules and declare that at said facility address, the

☒ a. portion(s) of the premises affected by the work is free of asbestos containing material (ACM).

☐ b. premise (or portions thereof) affected by the work contains 10 square feet or less or 25 linear feet or less of ACM.

Specify locations in section 9: Note: This material must be abated as a minor project in accordance with relevant provisions of the DEP Asbestos

☒ c. asbestos is present and will not be disturbed during construction activity. Specify the quantity and area where asbestos is present. Specify amount: 2900 sq. ft linear ft.

Specify locations (attach additional documents as necessary):

1st to 22nd Floor and Roof Bulkhead Exterior Walls Brickwork Components

☐ d. entire building is free of asbestos containing material (ACM).

9. RESULTS OF ASBESTOS BUILDING SURVEY:

FLOOR	DESCRIBE SECTION OF FLOOR	ALL MATERIALS ASSUMED TO CONTAIN ACM AND/OR SAMPLED	NUMBER OF SAMPLES ANALYZED	ASBESTOS PRESENT	ASSUMED ACM
1st to 22nd Floor	Facades Brickwork and Canopy Roof	Spandrel Flashing; Vertical & Horizontal Expansion Joints Caulking; Canopy Roofing & Flashing Materials	0	Yes	Yes
Roof	Bulkhead Exterior Walls	Spandrel & Base Flashing; Window & Door Frame Exterior Caulking	0	Yes	Yes

I hereby declare the information provided herein is true and complete

Mikhail Popovetskiy

MIKHAIL POPOVETSKIY

10/18/2012

113601

4/6/2013

DEP Certified Asbestos Investigator's Signature

Date

Certificate Number

Expiration Date

mikhail.popovetskiy@nycha.


Tel. # (718) 707-5223

Fax # (718) 707-5255

Email nyc.gov

The investigator shall assume that some or all of the areas investigated contain ACM, and for each area that is not assumed to contain ACM, collect and submit for analysis bulk samples in accordance with §§ 1-36, 1-37, and 1-44 of the DEP Asbestos Rules and EPA publications 560/5-85-024 and 560/5-85-030a and 40 CFR 763.86.

SEAL OF THE
NYC DEP
CERTIFIED
ASBESTOS
INVESTIGATOR



2549442



NYC DEPARTMENT OF ENVIRONMENTAL PROTECTION
Asbestos Control Program
59-17 Junction Boulevard, 8th Floor, Flushing, NY 11373
ASBESTOS ASSESSMENT REPORT



10. ANALYTICAL LABORATORY:

NAME	ELAP # (NYS DOH CERTIFICATION)	DATE(S) SAMPLES ANALYZED
------	--------------------------------	--------------------------

11. NYS DOL Asbestos Handling license # 29024 Company Name New York City Housing Authority

I hereby declare the information provided herein is true and complete


Mikhail Popovetskiy

<u>MIKHAIL POPOVETSKIY</u>	<u>10/18/2012</u>	<u>113601</u>	<u>4/6/2013</u>
DEP Certified Asbestos Investigator's Signature	Date	Certificate Number	Expiration Date
		<u>mikhail.popovetsky@nycha.</u>	

Tel. # (718) 707-5223 Fax # (718) 707-5255 Email nyc.gov

The investigator shall assume that some or all of the areas investigated contain ACM, and for each area that is not assumed to contain ACM, collect and submit for analysis bulk samples in accordance with §§ 1-36, 1-37, and 1-44 of the DEP Asbestos Rules and EPA publications 560/5-85-024 and 560/5-85-030a and 40 CFR 763.86.

SEAL
OF THE
NYC DEP
CERTIFIED
ASBESTOS
INVESTIGATOR



2549442