

NYC
Environmental
Protection

Carter H. Strickland, Jr.
Commissioner

James J. Roberts, P.E.
Deputy Commissioner
Bureau of Water &
Sewer Operations
jroberts@dep.nyc.gov

59-17 Junction Boulevard
Flushing, NY 11373

11/15/2013

Design Studio Associates
527 Court Street, Suite # C3
Brooklyn, New York 11231
Attn: Renzo Bolarte



To Whom It May Concern:

The hydrant flow test you requested in the vicinity of **1171 86th Street, Brooklyn** was performed on **11/13/2013** at **9:45 AM** the following results:

The static pressure taken on the north side of 86th Street 1st hydrant west of Twelfth Avenue was 60 pounds per square inch. The residual pressure at this point was 40 pounds per square inch when 500 gallons of water per minute were flowing from the north side of 86th Street 1st hydrant west of Eleventh Avenue.

This Department cannot guarantee that this pressure will be maintained in the future because a change may be needed in conformity with good engineering practices.

The flow test was performed on an 8 inch water main, which is fed from one direction.

If you have any questions regarding engineering, please contact (718) 595-7440, and for application status, please call (718) 595-3512.

Very truly yours,


Dudley Pierre, P.E.
Water Distribution Engineer
City Wide Hydraulic Testing Unit

File: FT2013-2119-302-970

All hydrant flow test requests are to be addressed to: NYCDEP-BWSO; 59-17 Junction Blvd, 12th Fl., Flushing; NY 11373-5108, Attn: Citywide Hydraulic Flow Test Unit

Enclose payment for \$500 payable to NYC Water Board for each test. Indicate the test street, cross streets and borough for each test. All requests are to be made by US or overnight mail, no hand deliveries accepted.