



**Environmental
Protection**

*Carter H. Strickland, Jr.
Commissioner*

James J. Roberts, P.E.
Deputy Commissioner
Bureau of Water &
Sewer Operations
jroberts@dep.nyc.gov

59-17 Junction Boulevard
Flushing, NY 11373

DEPT OF BLDGS 321187826 Job Number

ES413097184 Scan Code

October 30th, 2013

DeLaCour & Ferrara Architects, P.C.
91 Atlantic Avenue
Brooklyn, New York 11201
Attn: Kenneth W. Church Jr.

To Whom It May Concern:

The hydrant flow test you requested in the vicinity of ***west side of Fountain Avenue btw. Flatlands & Vandalia Avenues, Brooklyn*** was performed on ***10/18/2013 at 4:00 PM*** the following results:


The static pressure taken on the west side of Fountain Avenue 1st hydrant south of Flatlands Avenue was 62 pounds per square inch. The residual pressure at this point was 61 pounds per square inch when 500 gallons of water per minute were flowing from the west side of Fountain Avenue 2nd hydrant south of Flatlands Avenue.

This Department cannot guarantee that this pressure will be maintained in the future because a change may be needed in conformity with good engineering practices.

The flow test was performed on a 12 inch water main, which is fed from two directions.

If you have any questions regarding engineering, please contact (718) 595-7440, and for application status, please call (718) 595-3512.

Very truly yours,


Dudley Pierre, P.E.
Water Distribution Engineer
City Wide Hydraulic Testing Unit

File: FT2013-2068-331-122

All hydrant flow test requests are to be addressed to: NYCDEP-BWSO; 59-17 Junction Blvd, 12th Fl., Flushing; NY 11373-5108, Attn: Citywide Hydraulic Flow Test Unit

Enclose payment for \$500 payable to NYC Water Board for each test. Indicate the test street, cross streets and borough for each test. All requests are to be made by US or overnight mail, no hand deliveries accepted.