



PERMIT

Customer Name: MEHTA ANKIT Phone No.:
 Address: 02632 W 13 ST BROOKLYN 11233 Account No.: 7001058166001
 Cross Streets: BBL: 03-07225-0017
 Permit Type: PO-METER PERMIT METER Permit No: 847936 Fee: \$35.00
 PERMIT (POMTR)
 Issued By: MJ Issued Date: 08/01/2018 Expires: 08/01/2019

Permitted Activity:

PO-METER PERMIT INSTALL NEW 4" DCDA W/ 3/4" BYPASS MTR TO CVR E/P SPRINKLER SERVICE.

Tap Size: Service Size: Sprinkler Flag: Private Main:

Plumber Name: MURDOCCA ROCCO License No: 1890 Expires: 08/15/2019

Plumber Address: 517 DEGRAW STREET BROOKLYN, NY 11217

PERMIT ISSUED BY
THE CITY OF NEW YORK
BROOKLYN DEP/BCS



METER TEST RECORD

as at the registered head & wire run outside.
 or permanently removing a meter.
 must include a manufacturer's test clarification tag if installed or replaced a meter.
 at all required information.

Completed by the plumber to whom this permit was issued:

New Meter Serial No:

New Meter Make:

New Meter Size:

New Meter Register Type:

Date Set:

180090770
 Badger meter
 3/4"
 Bypass -
 09/20/18

ed, please indicate why:

ed.

☐ Other:

2018 AUG -3 A 11:07

DEP BCS

1800907703950220188
 Printed: 06/29/18

UNIT OF MEASURE

Duplicate Tag for NYC

High 99.2 % Int 100.7 % Low 100.22 %

ACCURACY TESTER NO.

3/4"m35

METER GEAR

SERIAL NUMBER

24747

I hereby certify that all information provided above is accurate, that
 all water and/or sewer connections are proper, that the premises is
 properly metered (where required) and that all work was performed
 in accordance with this permit and the Rules of the City of New York.

Plumber's Name:

Plumber's Signature:

Plumber's Address:

Rocco Murdocca
 Licensed Master Plumber #1890
 517 Degraw Street
 Brooklyn, NY 11217

Affix Seal Bellow:



PERMIT

Customer Name: MEHTA ANKIT **Phone No.:**
Address: 02632 W 13 ST BROOKLYN 11233 **Account No.:** 7001058166001
Cross Streets: **BBL:** 03-07225-0017
Permit Type: PO-METER PERMIT METER **Permit No:** 847931 **Fee:** \$75.00
PERMIT (POMTR)
Issued By: MJ **Issued Date:** 08/01/2018 **Expires:** 08/01/2019
Permitted Activity:
 PO-METER PERMIT INSTALL NEW 3" SJ MTR TO CVR E/P.
Tap Size: **Service Size:** **Sprinkler Flag:** **Private Main:**
Plumber Name: MURDOCCA ROCCO **License No:** 1890 **Expires:** 08/15/2019
Plumber Address: 517 DEGRAW STREET BROOKLYN, NY 11217
PERMIT ISSUED BY
THE CITY OF NEW YORK
BROOKLYN DEP/BCS

Additional Notes:

1. All meters must have all three wires at the registered head & wire run outside.
2. A final read is required if replacing or permanently removing a meter.
3. When returning this permit, you must include a manufacturer's test clarification tag if installed or replaced a meter.
4. Permit will not be accepted without all required information.

The following information MUST be completed by the plumber to whom this permit was issued:

Old Meter No.:

New Meter Serial No:

Old Meter Make:

CITY WATER METER REPAIR CO. I
Order # 18349550

Low: 99.9
 Medium: 99.9
 High: 99.9
 If final read on
☐ Meter missing



17112150

Model: 3" Q4
 Item: 5005Q2007XXWAXB
 Desc: 3" Q4 CF KENC 10M NYDEP W/WALL
 Date: 08/09/2018

CITY WATER METER REPAIR CO. I

Order # 18349550

Low 99.9
 Medium 99.9
 High 99.9
 17112150

Model: 3" Q4
 Item: 5005Q2007XXWAXB
 Desc: 3" Q4 CF KENC 10M NYDEP W/WALL
 Date: 08/09/2018

17112150

3" EVO

Q4

08/20/18

2018 AUG - 3 A 11:07

DEP BCS

I hereby certify that all information provided above is accurate, that all water and/or sewer connections are proper, that the premises is properly metered (where required) and that all work was performed in accordance with this permit and the Rules of the City of New York.

Plumber's Name:

Plumber's Signature:

Plumber's Address:

Rocco Murdocca

Licensed Master Plumber #1890

517 Degraw Street

Brooklyn, NY 11217

Afix Seal Bellow:



Date: September 6, 2018

BLOCK: 7225
LOT (S): 17

Vincent Sapienza
Commissioner

To Whom It May Concern:

This is to certify that the records of this bureau show that on 9/6/18

Anastasios Georgelis, P.E.
Deputy Commissioner
Bureau of Water &
Sewer Operations

New 8"x3" WC with 3" combined service.

connections@dep.nyc.gov

was installed for:

59-17 Junction Boulevard
Flushing, NY 11373

premises at 2632 West 13th St.

Borough of Brooklyn by plumber R. Murdocca

under permit no. 847939 and that the installation passes inspection
by this department on that date.

Very truly yours,

Selim Andrawis, P.E.,
Deputy Chief Connections



Date: September 6, 2018

BLOCK: 7225
LOT (S): 17

Vincent Sapienza
Commissioner

To Whom It May Concern:

This is to certify that the records of this bureau show that on 9/6/18

Anastasios Georgelis, P.E.
Deputy Commissioner
Bureau of Water &
Sewer Operations

New 8"x4" WC with 4" sprinkler service.

connections@dep.nyc.gov

was installed for:

59-17 Junction Boulevard
Flushing, NY 11373

premises at 2632 West 13th St.

Borough of Brooklyn by plumber R. Murdocca

under permit no. 847940 and that the installation passes inspection
by this department on that date.

Very truly yours,

Selim Andrawis, P.E.,
Deputy Chief Connections

THE CITY OF NEW YORK
DEPARTMENT OF ENVIRONMENTAL PROTECTION
BUREAU OF SEWERS

BOROUGH OF Brooklyn

CERTIFICATE OF INSPECTION - NEW SEWER HOUSE CONNECTION

The below described sewer house connection has been laid from the property line to the existing sewer at premises:

N.B. # 321197138 Block 7225 Lot 17
P.R.A.
Under Permit Number 848149 Issued 08/03rd, 20 18
Premises 2632 West 13th Road
house number and street
Located _____ side, _____ feet _____ of _____
Owner Ankit Mehta
Plumber Rocco Murdocca
Size and type of pipe laid 6" XHCZ (Storm)
Connected to 12" Storm Sewer laid in
size, type
West 13th Road
street, avenue

I hereby Certify that I made the inspection of the Sewer House Connection described above and that all work done under this permit has been properly completed in accordance with existing ordinances, rule and regulations.

Name J. Satizabal ELHAM RAKHAN
Inspector-Divison-Sewer Construction

Signed [Signature] Date: 08/31/18
Noted S. Indrawis Date: 9/4/18
Engineer in Charge


PENALTY FOR FALSIFICATION:

Falsification of any statement made herein is an offense punishable by a fine of imprisonment of both (N.Y.C. Administrative Code. Section 1151-90)

Copies to: Borough Superintendent, Department of Buildings
 Borough Office, Bureau of Water Register
 Sewer Regulation and Control Section
File original in Borough Office, Sewer Regulation & Control

2632	West 13 th Road	7225	17
house number	street name	block	lot

1. Was connection extended from curb connection? ☐ yes, ☒ no
2. Was the connection placed on earth, stone or crushed rock, concrete cradle, concrete encasement or reinforced concrete encasement? (circle one)
3. Was connection made to existing spur or riser or cut in? (circle one)
4. If connection was "cut in", was saddle or cutman used? (if so, circle)
5. Length, size and material of new connection 50' of 6" x 12"
6. Depth of connection at curb line is 4'-1" feet.
7. All work was exposed and inspected. 2632



date 08/31/13 .. signed [Signature] E. mwr

THE CITY OF NEW YORK
DEPARTMENT OF ENVIRONMENTAL PROTECTION
BUREAU OF SEWERS

BOROUGH OF Brooklyn

CERTIFICATE OF INSPECTION - NEW SEWER HOUSE CONNECTION

The below described sewer house connection has been laid from the property line to the existing sewer at premises:

N.B.# 321197138 Block 7225 Lot 17
P.R.A.

Under Permit Number 847941 Issued 08/01ST, 20 18

Premises 2632 West 13th Street
house number and street

Located _____ side, _____ feet _____ of _____

Owner Ankit Mehra

Plumber Rocco Murdocca

Size and type of pipe laid 8" XHCZ (Sanitary)

Connected to 10" Sanitary Sewer laid in
size, type
West 13th Street
street, avenue

I hereby Certify that I made the inspection of the Sewer House Connection described above and that all work done under this permit has been properly completed in accordance with existing ordinances, rule and regulations.

Name J. Satizaba / SM HASAN
Inspector-Divison-Sewer Construction

Signed [Signature] Date: 08/31ST/18

Noted S. Andrews Date: 9/4/18
Engineer in Charge

PENALTY FOR FALSIFICATION:


Falsification of any statement made herein is an offense punishable by a fine of imprisonment of both (N.Y.C. Administrative Code. Section 1151-90)

Copies to: Borough Superintendent, Department of Buildings
Borough Office, Bureau of Water Register
Sewer Regulation and Control Section
File original in Borough Office, Sewer Regulation & Control

2632	West 13 th Road	7225	17
house number	street name	block	lot

1. Was connection extended from curb connection? ☐ yes, ☒ no
2. Was the connection placed on earth, stone or crushed rock, concrete cradle, concrete encasement or reinforced concrete encasement? (circle one)
3. Was connection made to existing spur or riser or cut in? (circle one)
4. If connection was "cut in", was saddle or dutchman used? (If so, circle)
5. Length, size and material of new connection 40' of 8" x 11/2

6. Depth of connection at curb line is 4'-0" feet.
7. All work was exposed and inspected: 2632



date 08/31/18 signed [Signature]