



11/5/2015

Emily Lloyd
Commissioner

Speedy Expediting Inc.
110 Broadway
Brooklyn, New York 11249
Attn: Joel Mendelovits



To Whom It May Concern:

James J. Roberts
Deputy Commissioner
Bureau of Water &
Sewer Operations

59-17 Junction Blvd.
Flushing, NY 11373


The hydrant flow test you requested in the vicinity of **1479 Greene Avenue, Brooklyn** was performed on **11/3/2015** at **8:30 AM** with the following results:

The static pressure taken on an 8 inch water main which is fed from two directions on the west side of Greene Avenue 1st hydrant South of ST Nicholas Avenue was **41** pounds per square inch. The residual pressure at this point was **40** pounds per square inch when 500 gallons of water per minute were flowing from the west side of Greene Avenue 1st hydrant north of Wyckoff Avenue.

This Department cannot guarantee that this pressure will be maintained in the future because a change may be needed in conformity with good engineering practices.

If you have any questions regarding engineering, and application status, please call (718) 595-3958.

Very truly yours,


Jose A. Cortes, P.E.
Water Distribution Engineer
City Wide Hydraulic Testing Unit

File: FT2015-2621-317457

All hydrant flow test requests are to be addressed to: NYCDEP-BWSO; 59-17 Junction Blvd, 12th Fl., Flushing; NY 11373-5108, Attn: Citywide Hydraulic Flow Test Unit
Enclose payment for \$500 payable to NYC Water Board for each test. Indicate the test street, cross streets and borough for each test. All requests are to be made by US or overnight mail, no hand deliveries accepted.