

864807

Combined



DEPT BLDGS Job No. 321545155



Scan Code ESHS7417038

CERTIFICATE OF INSPECTION - NEW SEWER HOUSE CONNECTION

Borough of Brooklyn☐ Sanitary☐ Storm☒ Combination

This below described sewer house connection has been laid from the property line to the existing sewer at premises:

N.B.#/P.R.A. 821545155 Block 3019 Lot 13Under Permit Number 864807 Issued 2/8 20 19Premises 932 Grand Street
House Number and StreetOwner Leontine EbersPlumber Mohamed ABIFAZAKSize and type of pipe laid 8" x HCT

Connected to 30" Combined Sewer laid in
Size, Type
Grand Street
Street, Avenue

I hereby certify that I made the inspection of the Sewer House Connection described above and that all work done under this permit has been properly completed in accordance with existing ordinances, rule and regulations.

Name R. Johnson
InspectorSigned [Signature] Date: 2/26/19Signed [Signature] Date: 2/27/19
Chief

PENALTY FOR FALSIFICATION:

Knowing falsification of any statement is a misdemeanor under section 26-124 of the Administrative Code and is punishable by a fine or imprisonment, or both.

Copies to: ☐ Borough Superintendent, Department of Buildings
☐ Borough Office, Bureau of Water Register
☐ Sewer Regulation and Control Section


File original in Borough Office, Sewer Regulation and Control

HC 02 (REV 6/08)

nk
no pub.

932	Grand Street	3019	13
House Number	Street Name	Block	Lot

- Was connection extended from curb connection? ☐ Yes, ☒ No
- Was the connection placed on earth, stone or crushed rock, concrete cradle, concrete encasement or reinforced concrete encasement? (circle one)
- Was connection made to existing spur or riser, fold in sup, MH connection or cut in? (circle one)
- If connection was "cut in", was saddle or dutchman used? (if so, circle)
- Length, size and material of new connection Dep 40'-8" XHGI / DoB steel sleeve
- Depth of connection at curbline is 9' feet
- All work was exposed and inspected.



2019 FEB 27 A 8:36