



NYC DEPARTMENT OF ENVIRONMENTAL PROTECTION
Asbestos Control Program
 59-17 Junction Boulevard, 8th Floor, Flushing, NY 11373
ASBESTOS ASSESSMENT REPORT



1. NYC DOB Job # (if applicable) _____ **Control Number: 3255137**

2. Premise No. 17 Street Name Avenue F Borough Brooklyn Zip 11218

3. AKA 856 McDonald Avenue Type of Facility Other BIN _____ Block 5394 Lot 49

4. Building Owner Moshe Rosner Address 1917 50th Street

5. City Brooklyn State NY Zip 11204 Contact Person Moshe Rosner

6. Tel. # (347) 262-9085 Fax # _____ Email _____

7. Description of the Entire Scope of Work

Build new wall at rear of 1st floor store, and build concrete roof at rear of 1st floor to existing 3 story, 2 family and store brick building. No change to occupancy, egress, or zoning.

8. I, ANTHONY OROZCO, have conducted an asbestos investigation on
Name of Certified Asbestos Investigator

07/11/2016 3:30PM-3:45PM, 07/29/2016 12:45PM-1:00PM in accordance
Date(s)

with Sections 1-16 and 1-28 of the NYC DEP Asbestos Control Program Rules and declare that at said facility address, the

- ☒ a. portion(s) of the premises affected by the work is free of asbestos containing material (ACM).
- ☐ b. premise (or portions thereof) affected by the work contains 10 square feet or less or 25 linear feet or less of ACM.
 Specify locations in section 9: Note: This material must be abated as a minor project in accordance with relevant provisions of the DEP Asbestos Rules.
- ☒ c. asbestos is present and will not be disturbed during construction activity. Specify the quantity and area where asbestos is present. Specify amount: 600 sq. ft _____ linear ft.
 Specify locations (attach additional documents as necessary):
Attached garage roof (rear of 1st floor).
- ☐ d. entire building is free of asbestos containing material (ACM).

9. RESULTS OF ASBESTOS BUILDING SURVEY:

FLOOR	DESCRIBE SECTION OF FLOOR	ALL MATERIALS ASSUMED TO CONTAIN ACM AND/OR SAMPLED	NUMBER OF SAMPLES ANALYZED	ASBESTOS PRESENT	ASSUMED ACM
Cellar	West area of cellar	Concrete will be impacted by work.	0	No	No
1st Floor	West area of 1st floor retail unit	Sheet rock. Concrete will also be impacted by work.	2	No	No
Exterior	Attached garage roof	All existing roof materials will not be disturbed during work.	0	Yes	Yes
Exterior	West elevation of 3 story building & East elevation of garage	Mortar.	6	No	No


I hereby declare the information provided herein is true and complete

ANTHONY OROZCO 7/31/2016 122748 6/23/2017
DEP Certified Asbestos Investigator's Signature Date Certificate Number Expiration Date

Tel. # (347) 284-5697 Fax # _____

Email nebenvironmentalinc@yahoo.com

The investigator shall assume that some or all of the areas investigated contain ACM, and for each area that is not assumed to contain ACM, collect and submit for analysis bulk samples in accordance with §§ 1-36, 1-37, and 1-44 of the DEP Asbestos Rules and EPA publications 560/5-85-024 and 560/5-85-030a and 40 CFR 763.86.




Is it a Build-It-Back project? ☐ Yes, App ID # _____ ☒ No



25268582



NYC DEPARTMENT OF ENVIRONMENTAL PROTECTION
Asbestos Control Program
59-17 Junction Boulevard, 8th Floor, Flushing, NY 11373
ASBESTOS ASSESSMENT REPORT



10. ANALYTICAL LABORATORY:

NAME	ELAP # (NYS DOH CERTIFICATION)	DATE(S) SAMPLES ANALYZED
JLC Environmental Consultants, Inc.	11029	7/12/2016
ATC Group Services	10879	7/29/2016

11. NYS DOL Asbestos Handling license # 60195 Company Name North East Bronx Environmental, Incorporated

I hereby declare the information provided herein is true and complete

ANTHONY OROZCO 7/31/2016 122748 6/23/2017
DEP Certified Asbestos Investigator's Signature Date Certificate Number Expiration Date

Tel. # (347) 284-5697 Fax # _____

Email nebenvironmentalinc@yahoo.com

The investigator shall assume that some or all of the areas investigated contain ACM, and for each area that is not assumed to contain ACM, collect and submit for analysis bulk samples in accordance with §§ 1-36, 1-37, and 1-44 of the DEP Asbestos Rules and EPA publications 560/5-85-024 and 560/5-85-030a and 40 CFR 763.86.

SEAL
OF THE
NYC DEP
CERTIFIED
ASBESTOS
INVESTIGATOR



Is it a Build-It-Back project? ☐ Yes, App ID # _____ ☒ No



25268582