



11/23/2016

Vincent Sapienza, P.E.
Acting Commissioner

Anastasios Georgelis, P.E.
Acting Deputy Commissioner
Bureau of Water &
Sewer Operations

59-17 Junction Boulevard
Flushing, NY 11373

JW Fire Sprinkler Design
5 Mezabish Place, Unit # 201
Monroe, New York 10950
Attn: Jerry Pitera, P.E.

To Whom It May Concern:

The hydrant flow test you requested in the vicinity of **412 Herkimer Street, Brooklyn** was performed on **11/22/2016** at **11:23 AM** with the following results:

The static pressure taken on an 8 inch water main which is fed from two directions on the north side of Herkimer Street 2nd hydrant east of Kingston Avenue was **44** pounds per square inch. The residual pressure at this point was **42** pounds per square inch when 500 gallons of water per minute were flowing from the north side of Herkimer Street 1st hydrant west of Albany Avenue.

This Department cannot guarantee that this pressure will be maintained in the future because a change may be needed in conformity with good engineering practices.

If you have any questions regarding engineering, and application status, please call (718) 595-7135.

Very truly yours,

Urszula Krajewski, P.E.
Water Distribution Engineer
City Wide Hydraulic Testing Unit

File: FT2016-2525-316646

All hydrant flow test requests are to be addressed to: NYCDEP-BWSO; 59-17 Junction Blvd, 12th Fl., Flushing; NY 11373-5108, Attn: Citywide Hydraulic Flow Test Unit

Enclose payment for \$500 payable to NYC Water Board for each test. Indicate the test street, cross streets and borough for each test. All requests are to be made by US or overnight mail, no hand deliveries accepted.