



NYC DEPARTMENT OF ENVIRONMENTAL PROTECTION
Asbestos Control Program
59-17 Junction Boulevard, 8th Floor, Flushing, NY 11373
ASBESTOS ASSESSMENT REPORT



1. NYC DOB Job # (if applicable) _____ **Control Number: 3479238**
2. Premise No. 128 Street Name Meserole Street Borough Brooklyn Zip 11206
3. AKA _____ Type of Facility Commercial BIN 3071111 Block 03052 Lot 0008
4. Building Owner D&D CAFE LLC Address 128 MESEROLE STREET
5. City BROOKLYN State NY Zip 11206 Contact Person ANTHONY
6. Tel. # (917) 681-9845 Fax # _____ Email draftmaster@twcmetrobiz.com
7. Description of the Entire Scope of Work
INSTALL PLUMBING EXHAUST AND FIRE SUPPRESSION SYSTEM FOR
EXISTING RESTAURANT. NO CHANGE IN USE OCCUPANCY OR EGRESS.

8. I, REZA KHAMCY, have conducted an asbestos investigation on
Name of Certified Asbestos Investigator
09/20/2018 1:30AM-2:45AM in accordance

- Date(s)*
with Sections 1-16 and 1-28 of the NYC DEP Asbestos Control Program Rules and declare that at said facility address, the
- ☐ a. portion(s) of the premises affected by the work is free of asbestos containing material (ACM).
☒ b. premise (or portions thereof) affected by the work contains 10 square feet or less or 25 linear feet or less of ACM.
Specify locations in section 9: Note: This material must be abated as a minor project in accordance with relevant provisions of the DEP Asbestos Rules.
☐ c. asbestos is present and will not be disturbed during construction activity. Specify the quantity and area where asbestos is present. Specify amount: _____ sq. ft. _____ linear ft.
Specify locations (attach additional documents as necessary): _____
☐ d. entire building is free of asbestos containing material (ACM).

9. RESULTS OF ASBESTOS BUILDING SURVEY:

LOCATION	FLOOR NUMBER	DESCRIBE SECTION OF FLOOR	ALL MATERIALS ASSUMED TO CONTAIN ACM AND/OR SAMPLED	NUMBER OF SAMPLES ANALYZED	ASBESTOS PRESENT	ASSUMED ACM
Building Floors	1 to 5	Wall & Ceiling	Plaster	5	No	
Roof		Roof	Roofing Material	0	No	Yes

10. ANALYTICAL LABORATORY:

NAME	ELAP # (NYS DOH CERTIFICATION)	DATE(S) SAMPLES ANALYZED
KAM Consultants	11273	9/21/2018


I hereby declare the information provided herein is true and complete

REZA KHAMCY 9/22/2018 114293 5/23/2019
DEP Certified Asbestos Investigator's Signature Date Certificate Number Expiration Date

Tel. # (516) 860-4219 Fax # (516) 487-5077

Email rkhamcy@gmail.com

The investigator shall assume that some or all of the areas investigated contain ACM, and for each area that is not assumed to contain ACM, collect and submit for analysis bulk samples in accordance with §§ 1-36, 1-37, and 1-44 of the DEP Asbestos Rules and EPA publications 560/5-85-024 and 560/5-85-030a and 40 CFR 763.86, 40 CFR 763.80, 40 CFR 763.85.



Is it a Build-It-Back project? ☐ Yes, App ID # _____ ☒ No





NYC DEPARTMENT OF ENVIRONMENTAL PROTECTION

Asbestos Control Program
59-17 Junction Boulevard, 8th Floor, Flushing, NY 11373

ASBESTOS ASSESSMENT REPORT



11. NYS DOL Asbestos Handling license # 61173 Company Name ICON Engineering, P.C.

I hereby declare the information provided herein is true and complete

<u>REZA KHAMCY</u>	<u>9/22/2018</u>	<u>114293</u>	<u>5/23/2019</u>
DEP Certified Asbestos Investigator's Signature	Date	Certificate Number	Expiration Date

Tel. # (516) 860-4219 Fax # (516) 487-5077

Email rkhamcy@gmail.com

The investigator shall assume that some or all of the areas investigated contain ACM, and for each area that is not assumed to contain ACM, collect and submit for analysis bulk samples in accordance with §§ 1-36, 1-37, and 1-44 of the DEP Asbestos Rules and EPA publications 560/5-85-024 and 560/5-85-030a and 40 CFR 763.86, 40 CFR 763.80, 40 CFR 763.85.



Is it a Build-It-Back project? ☐ Yes, App ID # _____ ☒ No



25500464