



DEPT OF BLDGS340666835

Job Number



ES889918615

Scan Code

Architects • Planners

NYC Department of Buildings
Brooklyn Borough Office
210 Joralemon Street, 8th floor
Brooklyn, NY 11201

March 16, 2019

Re: Solar Panel Installation
Vito Residence
2033 East 67th Street
Brooklyn, NY 11234

Dear Sirs,

I've reviewed the proposed solar panel installation at this location to evaluate the existing roof structure and the connection of the panels to the roof.

<u>Criteria:</u>	Applicable codes:	2014 NYC Construction Code (w/ amendments) 2001 Wood Frame Construction Manual
	Design roof load:	20 psf live load, 10 psf dead load, 30 psf total load
	Design wind load:	110 mph, 35 psf; Exposure Category 'B'

My findings are as follows.

1. The new solar panels will imply an additional dead load of 3 psf. The existing roof structure (flat roof: 2x10 roof rafters @ 12" o.c., span = +/- 12'-0" to interior bearing) is sufficient to bear this additional load. Any inaccessible or concealed structural members not documented during the initial site analysis will be verified prior to the system installation. This analysis is based on the existing single layer of roofing but is also adequate for two layers of roofing.
2. The solar panels are attached to the roof with an adjustable tilt leg mounting system by Ironridge, with components as shown on the attached drawings. The mounting system, roof connections and connection spacing are rated for 110 mph. The canopy connections to the roof are 5/16" diameter x 6" long SS lag bolts.

It is a violation of NYSED 7209 for any person, unless acting under the direction of a licensed professional, to alter an item in any way. If an item bearing the seal of a licensed professional is altered, the altering licensed professional must attach the notation 'altered by' with his seal, signature, date of alteration, and description of the alteration.

I therefore certify that this installation complies with the applicable codes and design loads mentioned above, as well as ASCE 7-05, and is acceptable for approval. Please let me know if you have any questions on this information. Thanks!

Sincerely yours,

[Signature]

Tom Petersen

Cc: Swapnil Prabhu, Venture Home Solar

