




AI1: Additional Information Must be typewritten.



Page number 01 of 01 BIS Document No. 01

1 Location and Job Information Required for all applications.

House No(s) 1950 Street Name Oriental Boulevard
Borough Brooklyn Block 8760 Lot 60 BIN 3347724 CB No. 315

2 Revisions to Plans/Drawings Required whenever updating plans. All revisions for each page must be clearly described in section 3.

Submission is part of a Post Approval Amendment (PAA)? ☐ Yes PW1 required ☒ No Indicate all actions for this submission:

Action	Original/New/ Omit Page ID	Superseding Page ID	Action	Original/New/ Omit Page ID	Superseding Page ID	Action	Original/New/ Omit Page ID	Superseding Page ID	Action	Original/New/ Omit Page ID	Superseding Page ID

For "Action" use "N" for new page, "S" for superseding page, "O" for omitting page. Is this section continued on additional AI1 forms? ☐ Yes ☒ No

3 Additional Information Required for all applications.

Herewith submitting AI-1 for response to DOB Comments dated 07/23/19.

DOB Comment #1: Temporary fence to be filed as DOBNOW filing, and provide application number.

Response: With reference to drawing T-001.00: note has been added for contractor to file a separate application for temporary fence. Contractor's DOBNOW temporary fence application JOB NUMBER is B00197598.

DOB Comment #2: (a) Provide scaffolding/sidewalk shed application number. (b) Plans to show pedestrian safety and accessibility per BC 1103.1

Response: With reference to drawing T-001.00: (a) note has been added for contractor to file a separate application for scaffolding/sidewalk shed. Contractors scaffolding/sidewalk shed application JOB NUMBER is B00197598-I1-SH/SF; (b) pedestrian safety is means and methods of the contractor and its scaffolding/sidewalk shed application. Pedestrian routes affected by the job are not accessible routes.

DOB Comment #3: Demonstrate compliance with BB 2009-12.

Response: We are requesting waiver from this compliance as the project scope does not affect the flood zone of the building but is strictly limited to roof work located in the 3rd floor terrace.

With reference to drawing G-004.00: in addition to the already existing "Flood Hazard Area Notes", the note "I certify that this property is in a Tidal Wetlands, Freshwater Wetlands or Coastal Erosion Hazard area, but the category of work does not require compliance with LL 21/09." has been added.

Falsification of any statement is a misdemeanor and is punishable by a fine or imprisonment, or both. It is unlawful to give to a city employee, or for a city employee to accept, any benefit, monetary or otherwise, either as a gratuity for properly performing the job or in exchange for special consideration. Violation is punishable by imprisonment or fine or both. I understand that if I am found after hearing to have knowingly or negligently made a false statement or to have knowingly or negligently falsified or allowed to be falsified any certificate, form, signed statement, application, report or certification of the correction of a violation required under the provisions of this code or of a rule of any agency, I may be barred from filing further applications or documents with the Department.

Name (please print) Paul Millman, PE 07/30/19
Signature [Signature] Date
P.E. / R.A. Seal (apply seal, then sign and date over seal)

