



AI1: Additional Information

Must be typewritten.

☒ Orient and affix BIS
job number label here ☒

Page number _____ of _____

BIS Document No. _____

1 Location and Job Information *Required for all applications.*

House No(s) 2015

Street Name Pitkin Avenue

Borough Brooklyn

Block 3718

Lot 1

BIN 3083780

CB No. 305

2 Revisions to Plans/Drawings *Required whenever updating plans. All revisions for each page must be clearly described in section 3.*

Submission is part of a Post Approval Amendment (PAA)? ☐ Yes *PW1 required* ☐ No *Indicate all actions for this submission:*

Action	Original/New/ Omit Page ID	Superseding Page ID	Action	Original/New/ Omit Page ID	Superseding Page ID	Action	Original/New/ Omit Page ID	Superseding Page ID	Action	Original/New/ Omit Page ID	Superseding Page ID
S	A-001	A-001.01	S	A-102	A-102.01						
S	A-002	A-002.01									
S	A-100	A-100.01									
S	A-101	A-101.01									

For "Action" use "N" for new page, "S" for superseding page, "O" for omitting page.

Is this section continued on additional AI1 forms? ☐ Yes ☒ No

3 Additional Information *Required for all applications.*

As-Built Rev1, updated per DOB comments

A-001.01: Updated TR8 & TR1 descriptions

A-002.01: Updated Drawing #

A-100.01: The previous obstructions are not accurate, those are lamps on the parapet wall which wouldn't affect the clear path. They have been removed for clarify. Also, the parapet wall elevation above the roof level has been added

Since the parapet wall is at least 42" above the clear path, there is no need to install 42" tall railing in this area.

A-101.01: Elevations for the top of disconnect switch level, and roof slope have been added

A-102.01: Updated parapet wall elevation above the roof level. Also clarified the existing roof obstructions are roof HVAC units, thus the clearance path to the roof HVAC units are not needed.

I have self-certified compliance of objections. I am aware that the Commissioner will rely upon the truth and accuracy of the above statement as to compliance with the provisions of all applicable building laws and regulations. If non-compliance with such laws is disclosed at any later examination or review, I will take the necessary remedial measure to obtain objection compliance expeditiously. I further realize that any falsification of facts will render me liable for any legal and disciplinary action by the Department of Buildings and other appropriate authorities.

Falsification of any statement is a misdemeanor and is punishable by a fine or imprisonment, or both. It is unlawful to give to a city employee, or for a city employee to accept, any benefit, monetary or otherwise, either as a gratuity for properly performing the job or in exchange for special consideration. Violation is punishable by imprisonment or fine or both. I understand that if I am found after hearing to have knowingly or negligently made a false statement or to have knowingly or negligently falsified or allowed to be falsified any certificate, form, signed statement, application, report or certification of the correction of a violation required under the provisions of this code or of a rule of any agency, I may be barred from filing further applications or documents with the Department.


Name (ple:

Richard Ivins

Signature

Richard Ivins

P.E. / R.A. Seal (apply seal, then sign and date over seal)



12/08/2020

12/8/2020