




TR4: Technical Report
Soil Investigation
Must be typewritten.



1 Location Information Required for all applications.

House No(s) 214	Street Name VAN BUREN STREET				
Borough BROOKLYN	Block 1614	Lot 24	BIN 3043711	CB No. 303	
Work on Floor(s)			Apt/Condo No(s)		

2 Applicant Information Required for all applications.


Last Name PARBHUNATH	First Name INDARDEO	Middle Initial
Business Name IP CONCRETE TESTING & INSPECTION INC		Business Telephone 718-641-5800
Business Address 101-01 101 AVENUE		Business Fax
City QUEENS	State NY	Zip 11416
E-Mail aa inspectionsbuildings@gmail.com		License Number 083868
☒ P.E. ☐ R.A.		

3 Required Borings / Test Pits Required for all applications.

Number of Test Pits as Required as per NYC Construction Codes: B-1

4 Plot Diagram Required for all applications.

Draw in ink to indicate scale. Show building outline or extension and location of all borings and/or test pits by dimensions. Borings and/or test pits shall be distributed according to the NYC Construction Codes.



5 Test Report *Required for all applications.*

Date	Boring/ Test Pit #	Feet Below Curb	Soil Description	Class Number	Remarks
11/10/20	B-1	0-2	sandy clay, silt with broken bricks	6	Uncontrolled fill
		2-4	brown clayey clay (sc	3b	Natural fill
		4-6	brown sandy clay (sc	3b	Natural fill
		6-8	brown sandy clay with pebbles (sc	3b	Natural fill
		8-10	brown sandy clay with pebbles (sc	3b	Natural fill
		10-12	brown fine sand with pebbles (sm	3b	Natural fill
		12-14	brown fine sand with gravel (sm	3b	Natural fill
		14-16	brown fine sand with gravel (sm	3b	Natural fill
		16-18	brown fine sand with soft rocks (sm	1d	Natural fill
		18-20	brown fine sand with soft rocks (sm	1d	Natural fill
		20-22	brown fine sand with soft rocks (sm	1d	Natural fill
		22-24	brown fine sand with soft rocks (sm	1d	Natural fill
		24-25	brown fine sand with soft rocks (sm	1d	Natural fill
		25.5ft	Hit rock 25.5ft spoon refusal		

6 Statements and Signatures *Required for all applications.*

I hereby state that the above information is correct and complete to the best of my knowledge and that the above tests were performed in accordance with all Administrative Code Provisions and Departmental Rules, Regulations and Directives.

Falsification of any statement is a misdemeanor and is punishable by a fine or imprisonment, or both.

It is unlawful to give to a city employee, or for a city employee to accept, any benefit, monetary or otherwise, either as a gratuity for properly performing the job or in exchange for special consideration. Violation is punishable by imprisonment or fine or both.

Name (please print)

INDARDEO PARBHUNATH

11/10/2020

Signature

Date

P.E. / R.A. Seal (apply seal, then sign and date over seal)

Approvals - Internal Use Only

Examined and Recommended for Approval		Approved	
Examiner Name		Borough Commissioner Signature	Date
Signature	Date		