



Plumbing Division
Sprinkler Inspection Report

DEPT. BLDGS 410067145 Job Number
SC090310911 Scan Code

Premises 43-47 BYRD ST Borough QUEENS Date 12/03/2010
Approved Plan # 410067145 Stories 5 When Installed 03/03/2009
Construction BRICK&BLOCK Occupancy RESIDENTIAL Feet 60 Area 1-5
No. of water supplies 1 Wet or Dry WET

Supply: City Water Connection Size 3" Fed 2 ways ONE WAY
Curb or P.I. Valve CURB Name & size of meter 3/4"
Valves sealed open YES Lbs. Pressure 55 LBS

Gravity Tank Capacity N/A Heated N/A Height over top sprinkler line N/A
Size fill line N/A Size Overflow N/A Emergency Drain Valve N/A
Type and Size N/A Tank piping brass N/A Exposed piping weatherproofed N/A
Ladder secured N/A Location tank check and control valve N/A
Valves sealed open N/A No. Fill Pumps N/A Size N/A Type N/A
Capacity in gallons N/A How operated N/A

Pressure Tank Capacity N/A Tank House Heated N/A Size Fill Line N/A
Emergency Drain Valve N/A Type and Size N/A Air Pressure N/A
Water Level N/A Location tank check and control valves N/A
Control valves sealed open N/A

Risers No. 1 Size dead risers N/A Size live risers 3"
Size drain risers 2" Floor control valves YES Sealed open YES
Main Drain YES Size 2" Location inspectors Test valve TOP FLOOR
Exposed Piping or Heads HEADS Location 1-5 FL How protected HEATED BUILDING
No. Cold Weather Valves NONE Location N/A App'd signs YES

No. Dry Valves N/A Name N/A Type N/A Water Pressure N/A
Air Pressure N/A Dry Valve room heated N/A
No. of heads controlled by each dry pipe valve N/A

No. Alarm Valves N/A Size and type N/A Local N/A Supervisory N/A
High-Low Gravity N/A High-Low Pressure N/A Flow Alarm N/A

Fire Pumps: Name N/A Type N/A Capacity in Gallons N/A
Or
Booster Pumps: Checked N/A Draws from N/A Size of suction line N/A
Size of discharge line N/A How operated N/A Supervisory N/A
Adequate pressure in system N/A

No. Siamese connections NONE Size N/A App'd Type N/A
Location N/A Signs N/A Type of drips N/A
Caps painted green N/A
Is every square foot of the building sprinklered NO
If not, portion sprinklered EVERY 100 SQ FT
Extra heads & wrench provided YES Painted or corroded heads N/A

Is installation as per app'd plan YES As per Fire Dept. order NO
Entire system tested at 200 p.s.i. YES Result PASSED
Certificate of Fitness required NO

Recommendations:

OWNER'S NAME AND ADDRESS

CONTRACTOR'S NAME AND ADDRESS

KEVIN WEI
135-21 NORTHERN BLVD
FLUSHING, NY 11354

THE PLUMBING COMPANY, INC.
56-21 Marathon Pkwy., 2nd FL
Douglaston, NY 11362

Inspector (sign)

Inspector (print) CHIH H HSU

Test Listed
By

Report to: Div. Of Fire Prevention,
Fire Department