


Custom Lighting & Design



Performance

Electrical Services, Inc.

115 Florida Street · Farmingdale, New York 11735 · (631) 391-8433

Commercial • Industrial • Residential

Licensed & Bonded

6/19/09

TEST DATE:		
monthly	quarterly	✓
semi-annual	annual	
new install	✓	other:

LIFE'S WORC 251-40 GASKELL RD LITTLE NECK, N.Y.
JOB NAME

FIRELITE

CONTROL PANEL NAME:

9200

TYPE:

SERIAL #

BASEMENT

SYSTEM LOCATION:

	NO. OF DEVICES	NO TESTED	OKAY SEE BELOW
CONTROL PANEL (S)	1	1	✓
PULL STATIONS	9	9	✓
SMOKE DETECTORS	28	28	✓
HEAT DETECTORS	6	6	✓
SIGNAL BELLS/HORNS	9	9	✓
SIGNAL LIGHTS	5	5	✓
DOOR HOLDERS/MAGNETIC			
FAN/EQUIP. SHUTDOWN			
ANNUNCIATOR PNL			
WATER FLOWS			
CODE TRANSMITTERS			

TROUBLE DEVICES

BATTERIES

CHARGER (S) BATTERY

CENTRAL STATION

EMERGENCY LIGHTS

FIRE EXTINGUISHER

	NO OF DEVICES	NO TESTED	OKAY SEE BELOW
TROUBLE DEVICES	1	1	✓
BATTERIES	2	2	✓
CHARGER (S) BATTERY	1	1	✓
CENTRAL STATION	1	1	✓
EMERGENCY LIGHTS			
FIRE EXTINGUISHER			

LOCAL FIRE DEPT / CENTRAL STATION / OTHER

SIGNAL REC'D OPR. #

REMARKS

TIME:

ALL DEVICES AND EQUIPMENT FOR THIS SYSTEM TESTED AND FOUND TO BE FULLY OPERATIONAL
EXCEPT AS NOTED ABOVE IN REMARKS.

CUSTOMERS SIGNATURE

INSPECTORS SIGNATURE

John Medina