



New York City Department of
Environmental Protection
www.nyc.gov/dep

59-17 Junction Boulevard
Flushing, NY 11373

Steven W. Lawitts
Acting Commissioner

James J. Roberts, P.E.
Deputy Commissioner

Bureau of Water and
Sewer Operations

Tel (718) 595-5330
Fax (718) 595-5342
jroberts@dep.nyc.gov

August 14th, 2009



JLS Designs
214-41 42nd Avenue, Suite # 2C
Bayside, NY 11361
Attn: Joseph Sultana

To Whom It May Concern:

The hydrant flow test you requested in the vicinity of **23-28 30th Drive, Queens** was performed on **7/29/2009** at **1:30 PM** with the following results:

The static pressure taken on the north side of 30th Drive 1st hydrant west of Crescent Street was 54 pounds per square inch. The residual pressure at this point was 53 pounds per square inch when 500 gallons of water per minute were flowing from the north side of 30th Drive 1st hydrant east of 23rd Street.

This Department cannot guarantee that this pressure will be maintained in the future because a change may be needed in conformity with good engineering practices.

The flow test was performed on an 8 inch water main, which is fed from two directions.

If you have any questions on the above, please contact me at (718) 595-7029, fax at (718) 595-7408.

Very truly yours,

Edward Ayvazyan, P.E.
Water Distribution Engineer
City Wide Hydraulic Testing Unit

File: FT2009-0937-J30-0268

All hydrant flow test requests are to be addressed to: NYCDEP-BWSO; 59-17 Junction Blvd, 12th Fl., Flushing; NY 11373-5108, Attn: Citywide Hydraulic Flow Test Unit

Enclose payment for \$250 payable to NYC Water Board for each test. Indicate the test street, cross streets and borough for each test. All requests are to be made by US or overnight mail, no hand deliveries accepted.